

Project Number: 3-C2381.00

# Tekapo/Takapō Drinking Water Safety Plan

4 November 2022

PUBLIC



Mackenzie District Council



## Contact Details

### *Nicole Hunter*

WSP  
12 Moorhouse Avenue  
Christchurch 8011  
+64 3 363 5400  
+64 27 609 9981  
[nicole.hunter@wsp.com](mailto:nicole.hunter@wsp.com)

### *Lachlan Donaldson*

WSP  
12 Moorhouse Avenue  
Christchurch 8011  
+64 3 363 5400  
+64 27 298 8278  
[lachlan.donaldson2@wsp.com](mailto:lachlan.donaldson2@wsp.com)


### *Document Details:*

Date: 4 November 2022  
Reference: 3-C2381.00  
Status: Final

*Prepared by*  
Nicole Hunter



Lachlan Donaldson



*Reviewed by*



Bridget O'Brien

*Approved for release by*  
Fraser O'Malley



# Contents

Disclaimers and Limitations.....	1
1 Revision Details .....	2
2 About this Water Safety Plan .....	4
3 Commitment to Drinking Water Quality Management .....	6
3.1 Relationship of the Drinking Water Safety Plan to Organisational Policy and Strategy ...	6
3.2 Engaging Stakeholders and the Community .....	9
3.3 Te Mana o te Wai.....	12
4 Description of the Tekapo/Takapō Drinking Water Supply.....	15
4.1 Overview .....	15
4.2 Water Source and Water Quality.....	19
4.3 Treatment Plant and Treated Water Storage .....	22
4.4 Plant Control Measures and SCADA .....	24
4.5 Water Quality Characteristics .....	24
4.6 Distribution System.....	25
4.7 SCADA Control Measures and Alarms.....	26
5 Hazards and Hazardous Event Identification and Risk Assessment.....	27
5.1 Risk Assessment Methodology .....	27
5.2 Risk Assessment, Uncertainty and Acceptability .....	29
5.3 Risk Assessment Table .....	32
5.4 Unacceptable Risks.....	32
6 Source Water Risk Management Plan .....	33
6.1 National Environmental Standards for Sources of Human Drinking Water.....	33
6.2 Catchment Description .....	35
6.3 Climatic Features .....	38
6.4 Impacts of Catchment Activities on Water Quality.....	39
6.5 Cyanobacteria.....	39
6.6 Protozoa Log Removal Level .....	39
6.7 Values Identified by Local Authorities Under the National Policy Statement for Freshwater Management .....	39
7 Existing Preventive Measures and Barriers to Contamination.....	42
7.1 Introduction.....	42
7.2 Preventing Hazards Entering the Raw Water .....	42



7.3	Removing Particles, Pathogens, and Chemical and Radiological Hazards from the Water	42
7.4	Killing or Inactivating Pathogens in the Water	42
7.5	Maintaining the Quality of the Water in the Distribution System	42
7.6	Additional Mitigation Measures	43
7.7	Summary of Existing Preventive Measures	43
7.8	Effectiveness of Preventive Measures	43
8	Identification of Additional Preventive Measures and Improvement Plan	45
8.1	Improvements to Address Unacceptable Risks	45
8.2	Potential Additional Improvements	47
9	Operational Procedures	49
9.1	Operational Staff Training	49
9.2	Operations and Maintenance Manual	49
9.3	Standard Operating Procedures	49
9.4	Operations and Maintenance Activities	50
9.5	Operational Monitoring and Inspection	50
9.6	Critical Control Points	50
10	Verification Monitoring Programme	54
10.1	Drinking Water Quality Compliance Monitoring	54
10.2	Microbial Reduction from Water Treatment Processes	54
10.3	Consumer Satisfaction	56
10.4	Short-term Evaluation of Results	57
11	Management of Incidents and Emergencies	58
11.1	Previous Incidents and Emergencies	58
11.2	Incident and Emergency Response Plan	58
12	Documenting and Reporting	62
12.1	Management of Documentation and Records	62
12.2	Reporting	62
13	Investigations	63
13.1	Investigative Studies	63
13.2	Validation of Equipment, Processes and Practice	63
14	Oversight, Review and Continual Improvement	64
14.1	Long-term Evaluation of Results	64
14.2	Audit of Drinking Water Quality Management	64
14.3	External Audit of Drinking Water Quality Management	65

## List of Figures

Figure 3-1. Mackenzie District Council organisational chart.....	11
Figure 4-1 Tekapo/Takapō water supply sources and treatment plant map.....	16
Figure 4-2 Tekapo/Takapō water supply schematic showing barriers, control points and critical control points.....	17
Figure 4-3 Tekapo/Takapō water supply schematic including flow and water quality monitoring.....	18
Figure 4-4 Tekapo/Takapō drinking water supply source.....	19
Figure 4-5 Tekapo/Takapō chlorination treatment.....	22
Figure 4-6 Tekapo/Takapō water supply UV treatment plant.....	23
Figure 4-7 Treated water reservoir.....	23
Figure 6-1 Draft NES Source Water Risk Management Areas for River Sources (Ministry for the Environment, 2021).....	34
Figure 6-2 Draft NES Source Water Risk Management Areas for Aquifer Sources (Ministry for the Environment, 2021).....	34
Figure 6-3 Drinking Water Protection Zone (Land and Water Regional Plan) and SWMRA Zones for Fork Stream.....	35
Figure 6-4 Takapō/Tekapo water supply catchment land use.....	36
Figure 6-5 Wastewater discharge consents in the vicinity of the Takapō/Tekapo surface water catchment. Only showing in progress and active resource consents.....	37
Figure 6-6 Water take consents in the vicinity of the Takapō/Tekapo surface water catchment. Only showing in progress and active resource consents.....	37
Figure 6-7 Canterbury region median annual total rainfall.....	38
Figure 6-8 Canterbury region median annual temperature.....	38
Figure 6-9 Wetlands of Representative Importance.....	40
Figure 6-10 Takapō/Tekapo water take resource consent conditions. Resource CRC971414.....	41
Figure 9-1 Flowchart to help distinguish a CCP, taken from the Handbook for Preparing Drinking water safety plans.....	50

## List of Tables

Table 3-1 Documents related to the Tekapo/Takapō water supply.....	8
Table 3-2 Key stakeholders.....	9
Table 3-3 Te Mana o te Wai and water supply takes and infrastructure.....	13
Table 4-1 Tekapo/Takapō water supply scheme summary.....	16
Table 4-2 Raw water quality data.....	21
Table 4-3 Treated water quality data (treatment plant).....	24
Table 4-4 Treated water quality data (distribution system).....	24
Table 4-5 SCADA alarm set points.....	26
Table 5-1 Risk assessment - likelihood.....	27
Table 5-2 Risk assessment - consequence.....	28
Table 5-3 Risk assessment - scoring matrix.....	28
Table 5-4 Risk assessment - risk rating.....	28
Table 5-5 Risk assessment - uncertainty.....	29
Table 5-6 Risk assessment - acceptability.....	31
Table 5-7 Unacceptable risks.....	32
Table 6-1 Catchment impact.....	39
Table 6-2 Values Identified for the water sources.....	41
Table 7-1 Summary of effectiveness of preventive measures.....	44
Table 8-1 Improvement actions - unacceptable risks.....	46
Table 8-2 Additional improvement actions.....	47
Table 9-1 Staff training certificates and qualifications.....	49
Table 9-2 Tekapo/Takapō water treatment plant standard operating procedures.....	49
Table 9-3 Critical points and critical control points.....	51
Table 9-4 Chlorine disinfection CCP process objectives.....	52
Table 9-5 UV CCP process objectives.....	53



Table 10-1 Treated water quality specifications .....	54
Table 10-2 DWSNZ compliance - protozoal monitoring .....	55
Table 10-3 DWSNZ compliance assessment .....	55
Table 10-4 Annual Health Act compliance survey results .....	56
Table 11-1 Emergency / incident level descriptor .....	58
Table 11-2 Takapō/Tekapo water supply incident response plan .....	59

## Disclaimers and Limitations

This report (**'Report'**) has been prepared by WSP exclusively for Mackenzie District Council (**'Client'**) in relation to the Tekapo/Takapō Water Safety Plan (**'Purpose'**) and in accordance with the Short form Agreement with the Client dated 18/10/2021. The findings in this Report are based on and are subject to the assumptions specified in the Report. WSP accepts no liability whatsoever for any reliance on or use of this Report, in whole or in part, for any use or purpose other than the Purpose or any use or reliance on the Report by any third party.





In preparing the Report, WSP has relied upon data, surveys, analyses, designs, plans and other information (**'Client Data'**) provided by or on behalf of the Client. Except as otherwise stated in the Report, WSP has not verified the accuracy or completeness of the Client Data. To the extent that the statements, opinions, facts, information, conclusions and/or recommendations in this Report are based in whole or part on the Client Data, those conclusions are contingent upon the accuracy and completeness of the Client Data. WSP will not be liable in relation to incorrect conclusions or findings in the Report should any Client Data be incorrect or have been concealed, withheld, misrepresented or otherwise not fully disclosed to WSP.

# 1 Revision Details

## Version control

Version No	Description
V1	Prepared and approved by DWA in 2012.
V2	Prepared by Jim Graham, Principal Environmental Scientist, Opus International Consultants Ltd. Approved by DWA September 2017.
V3	Draft prepared by WSP NZ Ltd, August 2022
V4	Final copy submitted to MDC, November 2022

## Document review and approval

Role	Name	Signature	Date
Authors	Nicole Hunter (Engineer - Water, WSP)		12/10/2022
	Lachlan Donaldson (Engineer - Water, WSP)		12/10/2022
Reviewers	Bridget O'Brien (Technical Principal - Water & Wastewater, WSP)		21/10/2022
	Geoff Horler (3 Waters Manager, MDC)		9/11/2022
Approver	John Mackie (Acting Engineering Manager, MDC)		

The Water Services Act 2021 requires Taumata Arowai to maintain a register of drinking-water suppliers. The Tekapo/Takapō drinking water supply is owned by Mackenzie District Council, PO Box 52, Fairlie 7925 or 53 Main Street, Fairlie 7925. The operation and maintenance is undertaken by Whitestone Contracting Limited on behalf of Mackenzie District Council.

For the purposes of clarity:

- The Acting Engineering Manager, John Mackie, is the person responsible for the supply.
- 3 Waters Manager, Geoff Horler, is the primary contact for the supply.

### Assessment of the performance of the plan

Assessment of the performance of this drinking water safety plan will be undertaken annually, under the authority of the Chief Executive, and completed by the 3 Waters Manager. The assessment will consider any events, non-compliances, near misses and unexpected situations that have occurred during the past year, progress against the improvement schedule and any changes to any of the supply elements. Any matters requiring attention will be included into the Annual Plan, the Three Waters Asset Management Plan and if requiring significant capital funding, the Council's Long Term Plan.

### Reporting of the plan

A brief report on the performance of the plan, including information from the assessment of the plan will be completed and reported to the Engineering Manager annually on the anniversary of finalisation of the plan.



The report will cover the items listed above in the assessment of the performance of the plan. The 3 Waters Manager will be responsible for ensuring that any matters requiring attention will be appropriately included into the Annual Plan or the Asset Management Plan. If significant capital funding is required, the matter will be included into the Long Term Plan process (reviewed every three years).

### **Links to other quality systems**

This drinking water safety plan will be linked to the Council's Water Supply Asset Management Plan, Long Term Plan and Annual Plan.

## 2 About this Water Safety Plan

This drinking water safety plan has been prepared for the Tekapo/Takapō drinking water supply to identify potential events that present public health risks to consumers and reliability of supply. Mackenzie District Council (MDC) is committed to the principles of water safety planning and to the supply improvements that have been identified in this water safety plan.

Supply governance is in accordance with the statutory provisions and obligations of the Local Government Act 2002. Supply delivery falls within the expressed purpose of local government namely; *to enable democratic local decision-making and action by, and on behalf of, communities; and to promote the social, economic, environmental, and cultural well-being of communities in the present and for the future.*

The drinking water safety plan is aligned to national best practice and strengthens the focus on preventive measures across the whole drinking-water supply system, moving away from a reliance on after-the-event endpoint water quality testing. It promotes a multi-barrier approach to managing risks, which safeguards against the failure of any one barrier. It was prepared in accordance with the New Zealand Drinking-water Safety Plan Framework (Ministry of Health, 2018) and to meet the requirements of the Water Services Act 2021, including the requirement for a source water risk management plan. Taumata Arowai has advised that it is up to water suppliers to determine the format of their drinking water safety plan and that using the Ministry of Health framework is acceptable.

Tekapo/Takapō township is a small town located at the southern end of Lake Tekapo/Takapō in the Mackenzie district. The community includes residential housing, business and commercial areas and a school. The population is 552 people. The town is heavily tailored towards tourism with a significant number of accommodation providers and holiday homes (55% of dwellings in Tekapo/Takapō unoccupied (MacKenzie District Council, 2018)).

The Tekapo/Takapō drinking water supply is classified as a large drinking water supply under the Drinking Water Quality Assurance Rules (Taumata Arowai, 2022)<sup>1</sup>.

The water is sourced from an infiltration gallery adjacent to Fork Stream about seven kilometres northwest of Tekapo/Takapō township. The raw water is treated with chlorine gas before being piped to the water treatment plant. The water treatment plant contains a UV reactor for further disinfection and testing. The water is then stored in a reservoir before entering the reticulation system under gravity.

The maintenance and operation of the supply is undertaken by Whitestone Contracting Ltd under contract to MDC. Both are based in Fairlie. The key people responsible for management, maintenance and operation of the Tekapo/Takapō water supply scheme are:

- Acting Chief Executive – Angela Oorstuizen
- Acting General Manager, Operations, Planning and Regulatory Services – David Adamson
- Acting Engineering Manager – John Mackie
- 3 Waters Manager – Geoff Horler
- Treatment Plant Operator – John Wilson (Whitestone Contracting)

### Preparation of the plan

The drinking water safety plan was prepared by Nicole Hunter (Engineer – Water) and Lachlan Donaldson (Graduate Engineer – Water), overseen by Bridget O'Brien (Technical Principal – Water &

---

<sup>1</sup> Drinking Water Quality Assurance Rules (Taumata Arowai, July 2022):  
<https://www.taumataarowai.govt.nz/assets/Uploads/Rules-and-standards/Drinking-Water-Quality-Assurance-Rules-2022-Released-25-July-2022.pdf>

Wastewater, CPEng), with significant input from MDC staff via weekly meetings, a site visit and a risk workshop.

WSP staff undertook a site visit of the water supply escorted by Geoff Horler (3 Waters Manager) on 16 November 2021. A risk workshop was held on 16 November 2021 at MDC offices, facilitated by WSP and attended by Geoff Horler, Mike Davies (Project Manager) and John Wilson (Whitestone Contracting Ltd).

The pre-circulated draft risk register was discussed with a focus on unmitigated risks that were rated high or extreme. Further information about the water supply was obtained from MDC staff by phone and email, and through weekly meetings. Sections of the draft drinking water safety plan were submitted progressively to MDC for review between January and July 2022 and comments were received from Geoff Horler and Joni Johnson (former Engineering Manager). These comments were incorporated into the final drinking water safety plan

## 3 Commitment to Drinking Water Quality Management

### 3.1 Relationship of the Drinking Water Safety Plan to Organisational Policy and Strategy

Mackenzie District Council is committed to the six guiding principles for safe drinking-water as described in Taumata Arowai's Guidance on Drinking Water Safety Planning<sup>2</sup>:

- A high standard of care must be embraced
- Protection of source water is of paramount importance
- Maintain multiple barriers against contamination
- Change precedes contamination
- Suppliers must own the safety of drinking-water
- Apply a preventive risk management approach

The community outcomes that the Council's water supplies contribute to are 'a treasured environment', 'resilient successful communities', 'a strong and innovative economy' and to 'embrace heritage and diversity'. These community outcomes are described in the Council's 30 year Infrastructure Strategy and align with their vision statement 'to empower our communities and treasure our environment'.

#### 3.1.1 Legislative Requirements

The responsibility of providing drinking water by Council is undertaken in accordance with:

- Drinking-water Standards for New Zealand 2005 (revised 2018)
- Water Services Act 2021
- Resource Management Act 1991
- Local Government Act 2002
- Health and Safety at Work Act 2015
- Civil Defence and Emergency Management Act 2002
- National Policy Statement for Freshwater Management 2020
- National Policy Statement on Urban Development 2020
- Mackenzie District Council Water Supply, Wastewater and Stormwater Bylaw 2021

The Council must deliver the water supply service to comply with:

**Safe drinking water standards:** The Water Services Act, supported by the Drinking-water Standards for New Zealand (DWSNZ), specifies standards for drinking water quality and securing a safe supply. This will be replaced by the Drinking Water Quality Assurance Rules, Water Services (Drinking Water Standards for New Zealand) Regulations 2022 and the Aesthetic Values 2022 on 14 November 2022<sup>3</sup>.

**Drinking water safety plan:** Under the Water Services Act, a drinking water safety plan must be prepared for each of the Council's water supplies. The Council must manage and operate each water supply in accordance with the relevant drinking water safety plan.

**Abstraction of raw water:** The Council is consented in terms of the Resource Management Act 1991 on the volume of water which it may take from a given water resource.

---

<sup>2</sup> <https://www.taumataarowai.govt.nz/for-water-suppliers/drinking-water-safety-planning/guidance-for-drinking-water-safety-planning/#e636>

<sup>3</sup> Taumata Arowai, New Standards, Rules and Aesthetic Values:  
<https://www.taumataarowai.govt.nz/for-water-suppliers/new-compliance-rules-and-standards/>

**Water services assessments:** The Local Government Act 2002 requires a territorial authority to assess, from a public health perspective, the adequacy of its water supply in light of health risks, quality of service, current and future demand and regulatory compliance with drinking water standards.

**Fire flow:** Although the New Zealand Fire Service Firefighting Water Supplies Code of Practice is not mandatory, the Council provides fire hydrants as part of its urban water reticulation system. The Council endeavours to provide water for firefighting but does not guarantee a constant flow of water or any maximum or minimum pressure.

**Development capacity to meet demand:** The National Policy Statement on Urban Development 2020 directs local authorities to enable sufficient supply of land for houses and businesses and ensure that planning is responsive to changes in demand, while seeking to ensure that new development capacity enabled by Councils is of a form and in locations that meet the diverse needs of communities and encourages well-functioning, liveable urban environments.

**Emergency preparedness and response:** Under the Civil Defence and Emergency Management Act 2002, the Council as a local authority is required to plan and provide for civil defence emergency management in its district. It must be part of a Civil Defence Emergency Management Group and must provide suitably trained and competent personnel for effective civil defence emergency management in its area. As a lifeline utility, the Council as a water supplier must ensure that it is able to function to the fullest possible extent, even though this may be at a reduced level, during and after an emergency. It must also participate in the development of the national civil defence emergency management strategy and civil defence emergency management plans.

### *3.1.2 Long Term Plan and Annual Plan*

The Long Term Plan (2021 – 2031, adopted 14 December 2021) provides a 10-year plan for the Council. It is supported by the 30-year Infrastructure Strategy, Activity Plans, Asset Management Plans and a Financial Strategy. The purpose of the Long Term Plan is to:

- Describe outcomes the Council aims to achieve
- Specify the services, projects and budgets that will enable those outcomes
- Provide integrated decision-making and coordination of resources, as per section 93(6)(c) of the Local Government Act
- Provide a long-term focus
- Demonstrate transparency and accountability
- Provide an opportunity for participation by the public in Council decision-making processes.

The development of the Long Term Plan is supported by the preparation of the Water Supply Activity Management Plan. The Revenue and Financing Policy describes the revenue sources, the Financial Strategy sets out capital and operational expenditure for the next 10 years and the Infrastructure Strategy identifies the significant issues for the Council over the next 30 years, the options and planned approach for dealing with those issues and forecast capital and operational expenditure.

The draft Long Term Plan is released for public consultation, providing the Council's stakeholders (including the public) an opportunity to provide direct feedback on the Council's proposed priorities and associated budgeting. The Council took the feedback into account before finalising the Long Term Plan 2021 – 2031 on 14 December 2021.

The Long Term Plan is updated every three years. In the intervening two years, the Council undertakes an Annual Plan process. The plan for the coming year as set out in the Long Term Plan is reviewed, released for public consultation as a draft Annual Plan, and then finalised before the start of the financial year on 1 July.

Budgets for the water supply programme are determined through the Council’s Long Term Plan and Annual Plan processes. This includes budgets for work relating to water safety.

### 3.1.3 Documents related to the Tekapo/Takapō Water Supply

The documents related to the Tekapo/Takapō water supply are listed in Table 3-1.

Table 3-1 Documents related to the Tekapo/Takapō water supply

Name	Description	Location
Tekapo/Takapō Water Treatment Plant Operational Manual	Describes Tekapo/Takapō water supply operation and maintenance	A hardcopy is stored at the Tekapo/Takapō water treatment plant and at Council offices
Tekapo/Takapō Water Supply Standard Operating Procedures	Describes how the Tekapo/Takapō water supply should be operated and maintained.	Whitestone have electronic copies of SOPs. There is an improvement action in Section 8.2 for SOPs that are missing.
MDC Long Term Plan 2021-2031	Documents outlining the Council's priorities, activities, services, capital programme and operational expenditure and how the Council proposes to pay for it.	<a href="https://www.mackenzie.govt.nz/council/strategies-plans-and-reports/long-term-plan-2021-2031">https://www.mackenzie.govt.nz/council/strategies-plans-and-reports/long-term-plan-2021-2031</a>
Mackenzie District Plan	Document provides zonings and rules for Mackenzie Districts’ land to ensure that enough of each is available and is used for its intended purpose.	<a href="https://www.mackenzie.govt.nz/council/strategies-plans-and-reports/district-plan">https://www.mackenzie.govt.nz/council/strategies-plans-and-reports/district-plan</a>
MDC Annual Report 2021/22	Report on the performance of the Council, including water supply services	<a href="https://www.mackenzie.govt.nz/_data/assets/pdf_file/0005/629474/2020-2021-Annual-Report-Full.pdf">https://www.mackenzie.govt.nz/_data/assets/pdf_file/0005/629474/2020-2021-Annual-Report-Full.pdf</a>
MDC Water Supply, Wastewater and Stormwater Bylaws	Bylaws for the Mackenzie District, including a bylaw for water supply.	<a href="https://www.mackenzie.govt.nz/_data/assets/pdf_file/0009/589806/Water-Supply-Wastewater-and-Stormwater-Bylaw-2021.pdf">https://www.mackenzie.govt.nz/_data/assets/pdf_file/0009/589806/Water-Supply-Wastewater-and-Stormwater-Bylaw-2021.pdf</a>
Activity Management Plan for Water Supply 2021 - 2031	Outline Council’s long-term asset management approach for the provision and intergenerational management of water throughout the district	<a href="https://www.mackenzie.govt.nz/_data/assets/pdf_file/0007/596104/Mackenzie_DC_Water_AMP_2021_4.pdf">https://www.mackenzie.govt.nz/_data/assets/pdf_file/0007/596104/Mackenzie_DC_Water_AMP_2021_4.pdf</a>
Mackenzie District Council Map Viewer	Online GIS database showing locations of water supply assets	<a href="https://mapviewer.canterburymaps.govt.nz/?webmap=cdc3592cd33341fd9efe89361f754b59&amp;extent=1399870.5067900,1485000.5190500,2193">https://mapviewer.canterburymaps.govt.nz/?webmap=cdc3592cd33341fd9efe89361f754b59&amp;extent=1399870.5067900,1485000.5190500,2193</a>
Canterbury Civil Defence Emergency Management Group Plan 2018	Describes how the group will manage and respond to emergencies and sets out the operational arrangements of the group. MDC is a member of the group.	<a href="https://www.cdemcanterbury.govt.nz/media/bxwhxjcm/canterbury-cdem-group-plan-updated-june-2018.pdf">https://www.cdemcanterbury.govt.nz/media/bxwhxjcm/canterbury-cdem-group-plan-updated-june-2018.pdf</a>

Name	Description	Location
Mackenzie District Council Infrastructure Strategy 2021 - 2051	Describes how Council plans to manage its infrastructure (including water supply) over the next 30 years, taking into account issues facing the Mackenzie District. Capital and operating expenditure forecasts are included.	<a href="https://www.mackenzie.govt.nz/_data/assets/pdf_file/0008/596123/Infrastructure_Strategy_2021_-_Final_4_October_2021.pdf">https://www.mackenzie.govt.nz/_data/assets/pdf_file/0008/596123/Infrastructure_Strategy_2021_-_Final_4_October_2021.pdf</a>

## 3.2 Engaging Stakeholders and the Community

### 3.2.1 Key Stakeholders:

MDC maintains active working relationships with several key organisations and stakeholders. This allows for the ongoing management and operation of the supply, including emergency events or response to incidents relating to drinking water safety, quality, or continuity.

Table 3-2 lists the key stakeholders for the Tekapo/Takapō drinking water supply.

Figure 3-1 shows the MDC organisation chart for staff that have responsibility for three waters (water supply, wastewater, and stormwater).

Table 3-2 Key stakeholders

Stakeholder	Description/Relationship to supply management and operation	Contact Position	Contact Details
Taumata Arowai	Regulatory functions under the Water Services Act	Compliance Officer	<a href="https://www.taumataarowai.govt.nz/">https://www.taumataarowai.govt.nz/</a>
Regional Public Health	Public health services and regulatory functions under the Health Act.	Medical Officer of Health	<a href="https://www.cph.co.nz/">https://www.cph.co.nz/</a>
Mayor and Councillors	Exercises drinking water supply decision-making responsibilities in a transparent, inclusive and lawful manner in accordance with the Local Government Act.	Mayor Graham Smith, Council Chairman	<a href="https://www.mackenzie.govt.nz/council/mayor-and-councillors">https://www.mackenzie.govt.nz/council/mayor-and-councillors</a>
MDC Executive Leadership Team	Council's operational structure is divided into multiple groups responsible for council functions.	Angela Oosthuizen, CEO	<a href="https://www.mackenzie.govt.nz/council/executive-team">https://www.mackenzie.govt.nz/council/executive-team</a>
Canterbury Region Civil Defence Emergency Management Group	MDC is a member of the Canterbury Region CDEM which provides leadership and support to the community in a drinking water emergency and subsequent recovery.	Joe Rush, Emergency Operations Controller, MDC	<a href="https://www.cdem.canterbury.govt.nz/canterbury-cdem/governance-strategies-and-plans/">https://www.cdem.canterbury.govt.nz/canterbury-cdem/governance-strategies-and-plans/</a>
Environment Canterbury	Management and enforcement of RMA provisions in relation to water abstraction and allocation.	Resource Management Officer – Monitoring and Compliance	<a href="http://www.ecan.govt.nz">www.ecan.govt.nz</a> ; 0800 324 636
Fire and Emergency NZ	Response agency for CDEM events relating to drinking water. Major water user (flow and volume) during fire/emergency management incident response.	Carrie Lakin, Mackenzie Fire and Emergency Group Manager	027 405 9091

Stakeholder	Description/Relationship to supply management and operation	Contact Position	Contact Details
NZ Police	Response agency for CDEM events relating to drinking water.	Brad Morton, Senior Constable, Tekapo Police	021 191 2805
		Les Andrew, Senior Constable, Twizel Police	021 191 2324
		Russell Halkett, Senior Constable, Fairlie Police	03 685 8400
Alpine Energy	Operates and maintains the electricity distribution network serving treatment plants and related pump stations.	NA	<a href="https://www.alpineenergy.co.nz/">https://www.alpineenergy.co.nz/</a>
Whitestone Contracting Limited	Operation and Maintenance Contractor for the Twizel water supply reticulation network	Padraic Lawless	<a href="https://www.whitestone.co.nz/contact/">https://www.whitestone.co.nz/contact/</a>
Hills Laboratory	Provides IANZ and Taumata Arowai accredited water testing services	Craig Radford	<a href="https://www.hill-laboratories.com/">https://www.hill-laboratories.com/</a>
Arowhenua via Aoraki Consultant Services	Arowhenua is the principal Māori kainga of South Canterbury.	Treena Davidson, Senior Policy Advisor	<a href="https://arowhenua.org/">https://arowhenua.org/</a>
Cone Peaks Farm Ltd	Registered water carrier available if required - not under contract to MDC	Raymond Wallace Harrington	027 435 9632





# 3 Waters Assets & Operations Organisational Chart




Figure 3-1. Mackenzie District Council organisational chart

### 3.2.2 Maintenance Contractor

Whitestone Contracting Ltd is the operations and maintenance contractor for the Tekapo/Takapō water supply.

### 3.2.3 Public Consultation

Public consultation on the water supply is primarily through the Long Term Plan and Annual Plan process.

### 3.2.4 Incidents and Emergencies

Mackenzie District Council is a member of the Canterbury Region Civil Defence Emergency Management (CDEM) Group, which includes all local authorities in the Canterbury Region. The Canterbury region CDEM Group Plan was developed to provide effective and efficient management of significant hazards and risks and sets out the operational arrangements of the group. The Canterbury Region CDEM Group Public Information Team is responsible for providing accurate and timely communications to the public in the event of an emergency.

### 3.2.5 Customer Complaints

Customer complaints regarding water can be lodged on the Council website, email, post, free-call and in person at the Fairlie office or the Twizel office. Whitestone Contracting Ltd contact information is also provided on the council website.

## 3.3 Te Mana o te Wai

Policy 1 of the National Policy Statement for Freshwater Management is that freshwater is managed in a way that gives effect to Te Mana o te Wai. Te Mana o te Wai sets out to achieve the following:

- Recognise that protecting the health of freshwater (te hauora o te wai) protects the health and well-being of the wider environment (te hauora o te taiao) and of people (te hauora o te tangata)
- Protects the mauri of the wai

Giving effect to Te Mana o te Wai requires:

- Prioritising first the health and well-being of water bodies and freshwater ecosystems
- Active involvement of tangata whenua in freshwater management and decision-making
- An integrated approach recognising the interconnectedness of the whole environment, ki uta ki tai (from the mountains to the sea).

All elements of te taiao (the environment) possess their own mauri or life force.

Hauora is a holistic understanding of health and wellbeing:

- Te hauora o te taiao (the health of the environment), te hauora o te wai (the health of the waterbody) and te hauora o te tangata (the health of the people) are interconnected
- The state of health and wellbeing of te wai and te taiao is seen as a reflection on the mana, health and wellbeing of mana whenua
- Decline in te hauora o te wai and te hauora o te taiao is also understood to impact the health and well-being of the wider community

Ki uta ki tai is the concept used to describe holistic natural resource management, recognising all environmental elements are interconnected and must be managed as a whole. It is a way of understanding the natural environment, including how it functions, how people relate to it and how it can be looked after appropriately. Ki uta ki tai:

- Reflects mātauranga (indigenous knowledge) that all environmental elements are interconnected and must be managed as such
- Includes connections throughout a freshwater system, and also the relationships between air, land, freshwater and coastal waters
- Is concerned with each of the part of the system, and also the sum of the parts
- Requires holistic management.

Te Mana o te Wai approach does not ask, “Are the adverse effects within acceptable limits?” but rather it asks, “How are we supporting the health and wellbeing of the water body?” This affects system planning in the following ways.

- Respect the mauri of each water body:
  - Mauri is distinctive for each water body, reflecting whakapapa
  - Reflect natural form and function – letting the river be itself
  - The baseline for evaluating effects should be what happens naturally
  - Unnatural mixing of the mauri of different water bodies is not appropriate.
- Enable exercise of Kaitiakitanga:
  - Do not draw down “environmental capital”, but protect and sustain the water body for current and future generations
  - Do not manage to just meet bottom lines, but provide for healthy resilience, and do not rely on assimilative capacity; prevent contamination instead
- Mana whakahaere:
  - Partnership and active involvement of mana whenua in decision-making
  - Sustain iwi relationships with water bodies and provide for customary associations and uses – recognise wāhi tūpuna, avoid discharge of waste to water
  - Incorporate mātauranga
- Integrated management / ki uta ki tai:
  - Sustain and restore connections throughout catchment
  - Recognise connections between water body and coast
  - Sustain and restore habitats of mahinga kai and indigenous species
  - Consider relationships between land use and water use
  - Have regard to cumulative effects and climate change risks

Examples of how water supply takes, and associated infrastructure can support or be inconsistent with Te Mana o te Wai are summarised in Table 3-3.

Table 3-3 Te Mana o te Wai and water supply takes and infrastructure

Supports Te Mana o Te Wai	Inconsistent with Te Mana o Te Wai
Intake designed to allow natural flow to continue around it	Intake disrupts/diverts natural flow
Abstraction proportionate to natural flow	Abstraction takes all or most of natural flow
Maintains connections between surface water and groundwater	Treats surface water and groundwater as different resources
Ensures continuity of flow from mountains to sea	Considers only flow at point of take
Considers habitat needs holistically	Considers habitat factors narrowly

Supports Te Mana o Te Wai	Inconsistent with Te Mana o Te Wai
Intake designed to allow natural flow to continue around it	Intake disrupts/diverts natural flow
Structures located away from sensitive areas	Structures located close to mahinga kai or areas of dynamic river/coastal processes
Riparian buffers established and maintained	Structures built right next to river/ coastal margin
Fish are able to migrate naturally	Structures interrupt natural migration
Built-in resilience in terms of capacity and safeguards against overflows/leakage	Accepting a degree of overflow/failure as inevitable
Design for changing environment (especially due to climate change)	Reliance on structures/system designs that are no longer fit for purpose
Structures located away from sensitive areas	Structures located close to mahinga kai or areas of dynamic river/coastal processes

MDC gives effect to Te Mana o te Wai in the following ways:

- Engaging with mana whenua to understand the values they hold for the water bodies that MDC uses for its drinking water supplies.
- Resource consent applications for water takes have considered the wider effects on the water bodies that they draw from.
- There are no discharges of waste or chemicals to the environment from any of the water treatment plants.
- Dangerous chemicals are handled with care and measures are in place to contain spills.
- All water intake structures allow fish passage.
- Water from high quality sources is used, which results in higher quality drinking water, less waste and lower treatment costs.
- The source water risk management plans in this drinking water safety plan take an holistic view of the catchments.

MDC aims to improve how it gives effect to Te Mana o te Wai in the following ways:

- Increase water efficiency through installing smart meters on all water supply connections
- Continuing to improve water efficiency and reduce leakage in its water networks.

## 4 Description of the Tekapo/Takapō Drinking Water Supply

### 4.1 Overview

The Tekapo/Takapō drinking water supply was established in the 1950s when the town was a village serving workers on the Tekapo hydro-electric scheme. The town has since grown and now supports a range of tourist activities.

The supply currently abstracts water from an infiltration gallery adjacent to Fork Stream, located approximately 7 km northwest of Tekapo/Takapō township. It was installed in the 1996 and is accessed from Braemar Road. The infiltration gallery abstracts water from a depth of 6 to 8 m. Although the infiltration gallery is located within 130 m of Fork Stream, the groundwater quality is stable with stable turbidity of around 0.07 NTU. This suggests that the influence from surface conditions and the stream are minimal.

A limited amount of microbiological analysis of the source water has been undertaken which confirms intermittent low levels of contamination as would be expected from a source of this nature. The source is located on Council owned farmland, which is fenced off from stock.

A small treatment plant is located near to the infiltration gallery where abstracted water is disinfected with chlorine gas. Closer to Tekapo/Takapō another treatment building next to SH8 contains a UV reactor which disinfects all of the water.

From here the water flows under gravity to a storage reservoir located on a hill behind the Tekapo/Takapō township. This reservoir has a volume of 1,150 m<sup>3</sup> and provides approximately 20 hours of storage for Tekapo/Takapō at average demand (and 10 hours at peak demand). From the reservoir the water is supplied under gravity to the township. There is a booster station located at Lochinver Avenue to supply higher properties up Mistake Drive in peak demand.

Samples are collected and analysed for E. coli weekly from the treatment plant and from the distribution zone. Free available chlorine (FAC) is tested daily in the distribution system and weekly at the treatment plant. Turbidity is also tested weekly at the treatment plant.

The maintenance and operation of the supply is undertaken by Whitestone Contracting Ltd under contract to MDC. Operators visit the treatment plants at least weekly to check the operation of the chlorination and UV systems and test the FAC.

A catchment risk assessment was prepared in September 2017 and identified that the source water has a low risk of protozoal contamination and requires 3-log protozoa treatment. This was reviewed and confirmed in the source water risk assessment in section 6 of this water safety plan.

A map of the water supply scheme is shown in Figure 4-1 and the details of the scheme summarised in Table 4-1.




Figure 4-1 Tekapo/Takapō water supply sources and treatment plant map

Table 4-1 Tekapo/Takapō water supply scheme summary

Supply Management and Operation		
Supply Name	Tekapo	
Supply Code	TEK005	
Population Served by Supply	552	
Local Authority / Supply Owner	Mackenzie District Council	
Source Details		
Source Name	Fork Stream Infiltration Gallery	
Source Code	GO1588	
Type of Source	Groundwater	
Resource Consent No.	CRC971414	
Consent Expires	13 August 2033	
Maximum Consented Water Take:	Maximum rate of 40 L/s	
Grid Reference of Source (NZMG)	Easting: 1391434.9	Northing: 5128067.3
Treatment		
Plant Name	Tekapo	
Plant Code	TP00369	
Location	Braemar Road	



Grid Reference of Source (NZTM)	Easting: 1396104.7	Northing: 5124824.5
Treatment Processes	Chlorination, UV	
Average Daily Volume	1,268 m <sup>3</sup> /day	
Peak Daily Volume	2,681 m <sup>3</sup> /day	
<b>Distribution</b>		
Distribution Zone Name	Tekapo	
Distribution Zone Code	TEK005TE	
Distribution Zone Population	500	

#### 4.1.1 System Flow Diagrams

Figure 4-2 and Figure 4-3 show the water supply system, from source to reticulation, including the treatment plant. Figure 4-2 shows the barriers to contamination, critical points and critical control points which are discussed further in Section 9.6.




Figure 4-2 Tekapo/Takapō water supply schematic showing barriers, control points and critical control points




Figure 4-3 Tekapo/Takapō water supply schematic including flow and water quality monitoring



The draft MDC Water Activity Management Plan 2021 – 2031 states that population growth projections in the district “predict a relatively static population growth over the period of this asset management plan” and “there will not be a significant increase or decrease in demand for Council services based on change in population” (over the next 30 years). The available quantity of the source water meets the required needs of the current and future population, even during times of drought.

There are no significant projects identified in the AMP for the Tekapo/Takapō area.

## 4.2 Water Source and Water Quality

### 4.2.1 Intake Details

The Tekapo/Takapō supply abstracts water via an infiltration gallery, buried 6-8 m deep and approximately 160 m long. The ends of the infiltration gallery are visible in the photo in Figure 4-4.




Figure 4-4 Tekapo/Takapō drinking water supply source

The Tekapo/Takapō supply is consented as a groundwater take for up to 40 L/s under Resource Consent CRC971414.

The infiltration gallery is located well away from public areas, and access is through NZDF and private land. There is a rabbit-proof fence surrounding the intake.

### 4.2.2 Raw Water Quality

The raw water is analysed annually. Table 4-2 summarises the raw water quality results. Interpretation of the raw water data include:

- None of the determinands exceed the DWSNZ maximum acceptable values

- Alkalinity is consistently below the DWSNZ guideline value and should be corrected to prevent metals leaching from plumbing and fittings.
- pH was above guideline values in 2020 and 2021.
- Microbiological analysis of the source water is not routinely undertaken.

The tested parameters are available in Laserfiche under the heading:  
Corporate/Operations/Engineering/3 Waters/Tekapo/Water/Consents/Sampling with a folder set up for each calendar year.

Table 4-2 Raw water quality data

Parameter	Units	DWSNZ Guideline Value	DWSNZ Maximum Acceptable Value (MAV)	12/7/2016	10/11/2018	9/9/2020	9/13/2021
Total Alkalinity	g/m <sup>3</sup> as CaCO <sub>3</sub>	100-300		17.2	17	66	76
pH	pH units	7.0-8.5		7.1	6.9	9.2	9.2
Free Carbon Dioxide	g/m <sup>3</sup> at 25°C			2.5	3.8	< 1.0	< 1.0
Total Hardness	g/m <sup>3</sup> as CaCO <sub>3</sub>	200		14.4	14.1	48	58
Electrical Conductivity (EC)	µS/cm			36	32	131	149
Approx Total Dissolved Salts	g/m <sup>3</sup>	1000		24	21	88	100
Total Arsenic	g/m <sup>3</sup>		0.01			< 0.0011	< 0.0011
Total Boron	g/m <sup>3</sup>		1.4	< 0.0053	< 0.0053	< 0.0053	< 0.0053
Total Calcium	g/m <sup>3</sup>			5	4.9	19.1	23
Total Copper	g/m <sup>3</sup>	1	2	0.0088	0.0022	0.00071	0.00079
Total Iron	g/m <sup>3</sup>	0.2		< 0.021	< 0.021	0.122	0.056
Total Lead	g/m <sup>3</sup>		0.01			0.0005	0.0004
Total Magnesium	g/m <sup>3</sup>			0.46	0.44	0.131	0.099
Total Manganese	g/m <sup>3</sup>	0.04 Staining 0.10 Taste	0.4	0.00132	< 0.00053	0.0032	0.00185
Total Potassium	g/m <sup>3</sup>			0.21	0.176	5.7	5.7
Total Sodium	g/m <sup>3</sup>	200		1.41	1.29	6.6	6.8
Total Zinc	g/m <sup>3</sup>	1.5		0.0094	< 0.0011	0.093	0.052
Chloride	g/m <sup>3</sup>	250		0.5	< 0.5	< 0.5	< 0.5
Nitrate-N	g/m <sup>3</sup>		11.3	< 0.05	< 0.05	0.4	0.42
Sulphate	g/m <sup>3</sup>	250		1.7	2	1.4	1.4
			<b>Key:</b>	Less than MAV and GV	Exceeds GV or half the MAV	Exceeds the MAV	

## 4.3 Treatment Plant and Treated Water Storage

### 4.3.1 Chlorination

A small treatment plant is located near to the infiltration gallery off Braemar Road where abstracted water is disinfected with chlorine gas. Two 70 kg gas cylinders are installed at the treatment plant in a duty standby arrangement. When the duty bottle is near empty, it automatically changes over to the standby cylinder. The chlorine dose rate is automatically adjusted based on free available chlorine (FAC) monitoring data but the chlorine demand does not vary significantly due to the stable quality of the raw water.

The FAC is set to a target concentration of 0.3 mg/L to 0.4 mg/L leaving the UV treatment plant, and approximately 0.3 mg/L in the distribution network.

The FAC measurement from the UV treatment plant is transferred via a radio link to a controller in the chlorine treatment plant. The controller uses that FAC reading and the local flow meter reading to adjust the chlorine dose to a setpoint which the operators change occasionally to maintain the target FAC. There can be a delay in chlorine dose adjustment of up to 5 hours due to the distance to the sampling point.

The chlorine building is fitted with a chlorine gas leak sensor and audio / visual alarm, and the building is inspected weekly for abnormalities and replacements of gas bottles as required. Figure 4-5 shows photos of the chlorination plant.



Chlorine treatment building



70kg chlorine gas bottles

Figure 4-5 Tekapo/Takapō chlorination treatment

### 4.3.2 UV Treatment

Following chlorination, water is treated by a small UV reactor located in a building beside State Highway 8 next to the Tekapo/Takapō power substation. The data on UV intensity (UVI) and UV transmittance (UVT) is continuously monitored and telemetered to Whitestone's operator and the 3 Waters Manager at MDC. Treated water pH, flow, turbidity, FAC, UVI and UVT are monitored at the UV treatment plant. Weekly inspections of the UV treatment plant include calibration of turbidimeter and verification of UV intensity sensor. Figure 4-6 shows photos of the UV treatment plant.





Figure 4-6 Tekapo/Takapō water supply UV treatment plant

### 4.3.3 Treated Water Reservoir

The treated water reservoir (Figure 4-7) is located across the road and up the hill from the UV treatment plant and supplies Tekapo/Takapō under gravity. Access to the reservoir is restricted by a locked gate, and overlooked by a neighbouring property which deters vandalism.

The reservoir has a volume of 1,150 m<sup>3</sup> which provides approximately 2 days storage during winter, and 10 hours on a peak day.

The reservoir was relined with a liquid rubber coating in 2016 and is considered to be in good condition. The reservoir is covered and all entry hatches are secured. Grates and mesh over the air vent prevent access by vermin and insects.

The valve configuration allows the reservoir to be bypassed and Tekapo/Takapō supplied directly from the UV treatment plant if required.



Figure 4-7 Treated water reservoir

## 4.4 Plant Control Measures and SCADA

There is continuous monitoring of treated water pH, turbidity and FAC at the UV treatment plant. FAC monitoring results are used to control the chlorine dosing upstream.

The treatment plant has alarms for low UV intensity and pump faults.

There is an auto shutdown at the UV plant if power failure occurs.

## 4.5 Water Quality Characteristics

### 4.5.1 Treated Water Quality

The water quality monitoring results at the treatment plant for Tekapo/Takapō from the last five years is summarised in Table 4-3.

Table 4-3 Treated water quality data (treatment plant)

Parameter	DWSNZ GV	DWSNZ MAV	Minimum	Average	Maximum
Total Coliforms (MPN/100mL)			< 1	< 1	< 1
E. coli (MPN/100mL)		<1	< 1	< 1	< 1
Turbidity (NTU)	2.5		0.02	0.052	10.23
FAC (mg/L)		5.0	0.01	0.24	0.79
pH	7.0 - 8.5		3.3	5.6	7.5
Flow (m <sup>3</sup> /d)			0	176.3	571.7
UVT (%)			93	97.5	100

Interpretation of the treated water analysis include:

- There have been no detections of *E. coli* or total coliforms
- Turbidity is normally below the DWSNZ guideline value (GV), but was 10.23 mg/L on 14 July 2021 which exceeded the GV
- pH which was lower than the GV, due to instrument error.

The water quality data measured in the Tekapo/Takapō distribution system over the last five years is summarised in Table 4-4.

Table 4-4 Treated water quality data (distribution system)

Parameter	Maximum Acceptable Value (MAV)	Minimum	Average	Maximum
E. coli (cfu/100 mL)	1	< 1	< 1	3
Total Coliforms (MPN/100 mL)		< 1	< 1	11
FAC (mg/L)	5.0	0.04	0.27	0.86

Interpretation of the water analysis in the distribution system include:

- *E. coli* is generally below the DWSNZ MAV except for one transgression in 2020.
- FAC is generally above 0.2 mg/L and was consistently below the MAV of 5 mg/L. As DWSNZ bacterial compliance 6A is used for the distribution system, there is no requirement in DWSNZ to maintain a minimum concentration of FAC in the distribution system.

Disinfection by-products have not been monitored for the Tekapo/Takapō drinking water supply; therefore, it is unclear if there are any exceedances of the MAVs. There is an improvement action in Section 8 to address this unacceptable risk.

#### 4.5.2 *Water Quality Incidents and Responses*

There was one transgression recorded in the Tekapo/Takapō distribution system on 4 November 2020 with an *E. coli* concentration of 3 cfu/100 mL measured in the distribution network, and a total coliforms concentration of 11 MPN/100 mL. This transgression was attributed to poor sampling procedures.

## 4.6 **Distribution System**

### 4.6.1 *Asset Characteristics*

The water supply bulk supply main between the intake and the reservoir is approximately 6.8 km of DN 225 uPVC installed in 1999. The reticulation consists of 17.7 km of mostly PVC pipe (with some PE and AC pipe) gravity fed from the reservoir, 2.4 km of AC falling main (along SH8 from the reservoir to Beauchamp PI) and a 70 m single DN 200 Steel main crossing the Tekapo/Takapō River. The elevation difference between the reservoir and the Tekapo/Takapō township provides between 220 kPa and 470 kPa of pressure. There is a pump station located outside 26 Lochinver Avenue to boost pressure up Mistake Drive.

The distribution network was installed between 1955 and 2019 and is in generally good condition, with a pipeline renewals programme in place for assets nearing end of life.

### 4.6.2 *System Water Loss and Leakage*

The average daily consumption of 1720 L/person/ day<sup>4</sup> in the Mackenzie district far exceeds the industry standard in New Zealand of 280 L/person/day<sup>5</sup>. Based on minimum night flows, the leakage rate across the district is approximately 20%. Council is currently rolling out smart water metering in its water supplies as a demand management strategy to identify high water users and provide more detailed information on where leakage is occurring. Water metering is intended to drive a behavioural change where both the supplier and user are more likely to fix leaks once the quantity of water being lost is identified.

Known breaks and leaks are repaired as priority. However, due to the uncertainty of overnight flows and the nature of fast-draining gravels at Lakeside Drive, leaks and illegal connections are hard to identify. During winter some connections have taps constantly running to prevent freezing and loss of supply.

---

<sup>4</sup> Mackenzie District Council 2020/21 Annual Report:  
[/https://www.mackenzie.govt.nz/\\_data/assets/pdf\\_file/0005/629474/2020-2021-Annual-Report-Full.pdf](https://www.mackenzie.govt.nz/_data/assets/pdf_file/0005/629474/2020-2021-Annual-Report-Full.pdf)

<sup>5</sup> Water NZ National Performance Review 2020/2021:  
<https://www.waternz.org.nz/resourceuseefficiency>

## 4.7 SCADA Control Measures and Alarms

The treatment plant is monitored online using SCADA. All data in SCADA is stored every 15 minutes. The SCADA alarm set points for the plant are shown in Table 4-5. SCADA alarms are also raised for low UV dose, UV lamp failure and power outage.

The alarms are displayed on the screens in the treatment plant, as well as in SCADA which can be accessed via an app on operators' mobile phones; it also sends push notifications. The duty operator monitors and responds to alarms 24/7.

Table 4-5 SCADA alarm set points

Parameter	Low Alarm	High Alarm
FAC	0.5 mg/L leaving treatment plant	n/a
UV	45 mJ/cm <sup>2</sup>	n/a



## 5 Hazards and Hazardous Event Identification and Risk Assessment

### 5.1 Risk Assessment Methodology

Each element of the water supply is exposed to risk events of varying likelihood and consequence. In establishing a management plan, the level of risk to public health and operations within the water supply needs to be understood, quantified and managed.

The risk assessment includes identifying hazardous events and their likely causes. Hazardous events are defined as events that introduce hazards, or fail to remove them, from the water supply. The events and causes listed in the risk register were discussed and agreed upon in the risk assessment workshop held at Council offices with MDC staff on 16 November 2021. Likelihood and consequence scoring was done by means of expert judgement by workshop attendees (see Section 2 for a list of attendees).

A risk rating for each possible hazardous event was estimated based on the likelihood of the event occurring and the consequences if it does occur (Table 5-1 and Table 5-2). The matrix is based on five categories of likelihood and five categories of consequence (Table 5-3) which were discussed and agreed at the risk workshop.

The New Zealand Drinking-Water Safety Plan Framework (Ministry of Health, 2018)<sup>6</sup> allows a water supplier to establish its own approach to hazard identification and risk assessment methodology. The Handbook for Preparing a Water Safety Plan (Ministry of Health, 2019)<sup>7</sup> provides examples of likelihood and consequence ratings. The Council developed its own risk assessment methodology taking into account the examples given in the handbook and the World Health Organisation Water Safety Plan Manual 2009, which says that the aim of the risk assessment should be to distinguish between significant and less significant risks.

Table 5-1 Risk assessment – likelihood

Likelihood Frequency	Score	Likelihood Description
Almost Certain	5	Is expected to occur (more often than once per week)
Likely	4	Will probably occur (more often than once per month and up to once per week)
Possible	3	Might occur at some time (more often than once per year and up to once per month)
Unlikely	2	Could occur at some time (more often than once every 5 years and up to once per year)
Rare	1	Expected to occur only in exceptional circumstances (greater than once every 5 years)

<sup>6</sup> Ministry of Health, 2018: New Zealand Drinking-water Safety Plan Framework: <https://www.health.govt.nz/publication/new-zealand-drinking-water-safety-plan-framework>

<sup>7</sup> Ministry of Health, 2019: Handbook for Preparing a Water Safety Plan: <https://www.health.govt.nz/publication/handbook-preparing-water-safety-plan>

Table 5-2 Risk assessment – consequence

Consequence Ranking	Score	Description
Catastrophic	5	Major impact on most of the population, complete failure of systems, requirement for high level of monitoring and incident management. Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected
Major	4	Major impact on a sub-population, significant compromise of systems and abnormal operation, requirement for high level of monitoring and incident management. Potential acute harm to people, declared outbreak or widespread illness expected.
Moderate	3	Minor impact on most of the population, significant (but manageable) disruption to normal operation, requirement for increased monitoring. Potential widespread aesthetic issues, or repeated breach of maximum acceptable value (MAV).
Minor	2	Minor impact on a sub-population, some manageable disruption to normal operation. Potential local aesthetic issues, isolated exceedance of MAV.
Insignificant	1	Insignificant impact, little disruption to normal operation. Isolated exceedance of aesthetic parameter.

A semi-quantitative risk prioritisation approach was used where each likelihood and consequence category received a score between 1 and 5 as detailed above, and the combined risk score determines the overall risk rating as per Table 5-3 and Table 5-4.

Table 5-3 Risk assessment – scoring matrix

		Consequence				
		Insignificant	Minor	Moderate	Major	Catastrophic
Score		1	2	3	4	5
Rare	1	1	2	3	4	5
Unlikely	2	2	4	6	8	10
Possible	3	3	6	9	12	15
Likely	4	4	8	12	16	20
Almost Certain	5	5	10	15	20	25

Table 5-4 Risk assessment – risk rating

Risk Score	1 - 4	4 - 9	10 - 16	20 - 25
Risk Rating	Low	Medium	High	Extreme

## 5.2 Risk Assessment, Uncertainty and Acceptability

A range of factors contribute to the consequence of an event; including economic, environmental, public health, and operational impacts. This document only considers public health and operations effects, with emphasis placed on public health risks.

The Risk Table gives details of the maximum risk and residual risk i.e. without any measures in place and barriers failed, and with existing preventive measures in place respectively.

Hazard identification and risk assessment are activities of informed judgement and contain uncertainty and limitations. Uncertainty arises from factors such as lack of or variability in data and/or information. These uncertainties and limitations need to be understood and taken into consideration when determining acceptability of risks. Risk uncertainty descriptors are provided in Table 5-5. In general, an uncertain or estimated risk elevates the risk acceptability and requires further investigation.

Table 5-5 Risk assessment – uncertainty

Level of certainty	Description
Certain	<p>At least five years of:</p> <ul style="list-style-type: none"> <li>• Continuous data (e.g., FAC), or</li> <li>• Monitoring data (e.g., <i>E. coli</i> monitoring), or</li> <li>• Monthly monitoring data (chemical), or</li> <li>• Inspection records which have been collated and analysed, and variability is predictable</li> <li>• At least five years of continuous/daily/monthly monitoring/inspection data for the duration of seasonal events which have been collated and analysed, and variability is predictable.</li> <li>• The hazardous event and preventive measures/processes involved are thoroughly understood.</li> </ul>
Confident	<p>At least two years of:</p> <ul style="list-style-type: none"> <li>• Continuous data (e.g., FAC), or</li> <li>• Daily monitoring data (<i>E. coli</i> monitoring), or</li> <li>• Monthly monitoring data (chemical), or</li> <li>• Inspection records which have been collated and analysed, and variability is predictable.</li> <li>• At least two years of continuous/daily/monthly monitoring/inspection data for the duration of seasonal events, which have been collated and analysed, and variability is predictable.</li> <li>• There is a good understanding of the hazardous event and preventive measures/processes involved.</li> </ul>

Level of certainty	Description
Reliable	<p>At least one year of:</p> <ul style="list-style-type: none"> <li>• Continuous data (e.g., FAC), or</li> <li>• Daily monitoring data (<i>E. coli</i> monitoring), or</li> <li>• Monthly monitoring data (chemical), or</li> <li>• Inspection records which have been collated and analysed, and variability is predictable.</li> <li>• At least two years of continuous/daily/monthly monitoring/inspection data for the duration of seasonal events have been collated and analysed, but variability is not predictable.</li> <li>• There is a good understanding of the hazardous event and preventive measures/processes involved.</li> </ul>
Estimate	<ul style="list-style-type: none"> <li>• There are limited monitoring data available.</li> <li>• There is a reasonable understanding of the hazardous event and preventive measures/process involved.</li> </ul>
Uncertain	<ul style="list-style-type: none"> <li>• There are limited or no monitoring data available.</li> <li>• The hazardous events or preventive measures/processes are not well understood.</li> </ul>

Table 5-6 outlines the levels of risk considered:

- Acceptable risk – no further actions required to reduce the risk
- Unacceptable risk – additional actions / improvements to be taken.

Table 5-6 Risk assessment – acceptability

Risk level	Certainty	Acceptability	Management actions
Low	Certain	Acceptable	Manage within existing processes, adopting continuous improvement.
	Confident		
	Reliable		
	Estimate		
	Uncertain		
Medium	Certain	Acceptable	Implement short-term measures, and plan and implement longer-term risk reduction measures within x-year timeframe.
	Confident		
	Reliable		
	Estimate	Unacceptable	Implement short-term measures, and investigate measures to reduce level of uncertainty as soon as possible.
	Uncertain		
High	Certain	Unacceptable	Implement short-term measures immediately, and prioritise longer-term risk reduction measures.
	Confident		
	Reliable		
	Estimate	Unacceptable	Implement short-term measures immediately, and investigate measures to reduce level of uncertainty as soon as possible.
	Uncertain		
Extreme	Certain	Unacceptable	Implement short-term measures immediately, put emergency plans on stand-by and give longer-term risk reduction measures top priority.
	Confident		
	Reliable		
	Estimate	Unacceptable	Implement short-term measures immediately, put emergency plans on stand-by and immediately investigate measures to reduce level of uncertainty.
	Uncertain		

The Council has determined that a medium risk where the level of uncertainty is classified as ‘Certain’, ‘Confident’, or ‘Reliable’ is an acceptable risk, as illustrated in

Table 5-6. This is in line with the World Health Organisation Water Safety Plan Manual 2009, which says that the aim of the risk assessment should be to distinguish between significant and less significant risks.

Unacceptable risks requiring improvements have been identified in the improvement tables in Section 8.1. The responsibility for ensuring progress on the improvement, the timeframe for the improvement, and possible practical steps to carry out the improvement are also included in the tables.

To ensure that the work is undertaken, responsibilities have been assigned to the relevant Council staff. Roles and responsibilities are likely to change and therefore are required to be checked as part of the annual internal drinking water safety plan review process.

### 5.3 Risk Assessment Table

The Tekapo/Takapō drinking water supply risk assessment table is provided in Appendix A.

### 5.4 Unacceptable Risks

The assessment of risk acceptability and level of uncertainty in Appendix A has identified two risks that are considered unacceptable and are listed in Table 5-7. Existing programmes and measures are described in this section, and additional improvements to address these risks outlined in Section 8.1

Table 5-7 Unacceptable risks

Supply Element	Event Description	Cause No.	Possible Causes
Treatment - Chlorination	Production of disinfection by-products	2.05	Organic material in raw water results in the production of disinfection by-products
Reticulation	Chemical/Microbiological Contamination	4.08	Backflow from consumer connections

#### 5.4.1 Risk 2.05 – Production of disinfection by-products due to organic material in raw water

Disinfection by-products (DBPs) have the potential to cause a repeated breach of MAVs. This is considered likely due to a high organic loading in source water without a filtration process prior to chlorination. Gas chlorine is less likely to create disinfection by-products than hypochlorite. Due to lack of testing of DBPs, the uncertainty of this medium risk classifies it as unacceptable.

The improvement actions to mitigate this risk is:

- Monitor disinfection by-products.

#### 5.4.2 Risk 4.08 – Introduction of contamination due to no / inadequate / faulty / incorrectly installed backflow prevention device

Contaminants entering the drinking water supply due to backflow or back siphonage poses a contamination hazard to the distribution system. A lack of backflow prevention devices (as well as inadequate, faulty or incorrectly installed backflow devices) means that there is insufficient protection to reduce the likelihood of contaminants entering the drinking water supply.

The improvement actions to reduce this risk are:

- Undertake a survey of commercial customers to determine backflow hazard (complete)
- Install backflow prevention on high and medium hazard connections
- Test all testable backflow prevention devices annually
- Create and maintain a backflow register
- Undertake assessment of backflow risk for residential connections.

## 6 Source Water Risk Management Plan

Source water risk management plans (SWRMPs) are a new requirement in the Water Services Act 2021. MDC has chosen to include a source water risk management plan as part of this drinking water safety plan. It is considered that the requirements of the Water Services Act are met as follows:

- This section of the WSP meets the requirements of section 43(1)
- The risk assessment, preventive measures and improvement plan in sections 5, 7 and 8 of the WSP meet the requirements of sections 43(2)a – c.
- The consideration of values identified by local authorities in section 6.4 of the WSP meets the requirements of section 43(2)d.
- Information about land use activities, potential sources of contamination, other water users and water quality data is included in section 4.2 of the WSP and meets the requirements of section 43(4)a(i-ii)
- The risk assessment in section 5 of the WSP meets the requirements of section 43(4)(a)(iii)
- The improvement actions agreed to by the local authority in section 8 meet the requirements of section 43(4)(b).

### 6.1 National Environmental Standards for Sources of Human Drinking Water

The current National Environmental Standards for Sources of Human Drinking Water 2007 (NES-DW) forms part of the multiple barrier approach applied in New Zealand ensure safe drinking water is supplied to customers.

The existing NES-DW requires regional councils to identify certain activities within a source water catchment and determine if they will have an adverse effect on source water quality (resulting in MAVs in excess of DWSNZ limits following treatment). The draft NES-DW proposes defining three source water risk management areas (SWRMAs) as defined below and depicted on Figure 6-1 (for river sources) and Figure 6-2 (for aquifer sources).

- **SWRMA 1** is the immediate area around the source water take where there is an immediate risk of contamination because there is very little time to respond to any contamination before it enters the water supply.
  - For aquifers, it encompasses land within a 5-metre radius around the intake (bore head).
  - For rivers, it encompasses the river and its bed 1,000 m upstream and 100 m downstream of the intake, extending 5 m into land from the river edge.
- **SWRMA 2** is a larger area where activities need to be managed, to mitigate more medium-term risks of contamination. The size will vary because it is based on the time it takes for water to flow to the source.
  - For aquifers, it is the land area above where groundwater travels to the intake (bore) within a 1-year period, to a maximum of 2.5 kilometres.
  - For rivers, it is the river and bed from where water travels to the intake within an 8-hour period.
- **SWRMA 3** is the entire catchment area for the source water. Persistent contaminants and cumulative effects of all activities within the catchment are the management focus in this area, and they are considered to be appropriately managed under the RMA. The proposed amendments to the NES-DW aim to clarify that consenting decisions must address source water risks.






Figure 6-1 Draft NES Source Water Risk Management Areas for River Sources (Ministry for the Environment, 2021)




Figure 6-2 Draft NES Source Water Risk Management Areas for Aquifer Sources (Ministry for the Environment, 2021)

As the Tekapo/Takapō water supply is from an infiltration gallery, the SWRMA zones must include both the surface water catchment and the catchment of the aquifer that feeds the infiltration galleries. As seen in Figure 6-2 the extent of the SWRMA Zone 1 for the aquifer catchment is contained entirely within the surface water SWRMA Zone 1.



The SWRMA Zone 2 for the aquifer source has been shown as a 2.5 km radius around the water take.

The combined SWRMA zone 3 comprises of the 2.5 km radius for the aquifer source SWRMA Zone 2 and the entire surface water catchment and is shown in Figure 6-4 to Figure 6-6. It is assumed that this is the entire catchment for the aquifer source.




Figure 6-3 Drinking Water Protection Zone (Land and Water Regional Plan) and SWMRA Zones for Fork Stream.

## 6.2 Catchment Description

The catchment upstream of the infiltration gallery and its land use is shown in Figure 6-4. The land immediately surrounding the infiltration gallery is owned by MDC and has been fenced to exclude stock animals. The fence is 60 m from the infiltration gallery, and is designed to keep rabbits out of the intake area. While on site for the cyanobacteria risk assessment, evidence of deer activity was noticed within the fenced area. The upper part of the catchment is owned by the Department of Conservation and the lower part by the Ministry of Defence. Both are aware that the catchment is used for drinking water. No farm stock is kept on this land.

Wild and feral animals in the lower portion of the catchment will contribute some microbiological contamination to the catchment. Very little microbiological contamination would be expected to occur in the upper reaches of the catchment, reflecting the low populations of animals due to the severity of the alpine environment.

The catchment has no human habitation and very few human activities are performed in the catchment except for military exercises. This would be a minor source of microbiological contamination in the catchment.

There are no resource consents granted in the catchment upstream of the intake. Nearby resource consents to discharge wastewater are shown in Figure 6-5 and are well downstream of the water

take. There is one additional resource consent (CRC171755) for other water takes in the catchment as shown in Figure 6-6. This consent allows the take of water for stock water and wetland enhancement from Fork Stream. There are no buildings or septic tanks in the catchment. There are no known natural hazards in the catchment.

ECan has provided information about hazardous activities in the catchment (Hazardous Activities and Industries List). There are no contaminated sites identified in the catchment.




Figure 6-4 Takapō/Tekapo water supply catchment land use






Figure 6-5 Wastewater discharge consents in the vicinity of the Takapō/Tekapo surface water catchment. Only showing in progress and active resource consents.



Figure 6-6 Water take consents in the vicinity of the Takapō/Tekapo surface water catchment. Only showing in progress and active resource consents.

### 6.3 Climatic Features

Climate related factors influencing catchment conditions and demand for water include rainfall and temperature. According to NIWA models (see Figure 6-7 and Figure 6-8) median annual total rainfall in the Takapō/Tekapo catchment is 500 – 600 mm/year and the median temperature is 9 – 10 °C

NIWA Future Climate Predictions anticipate an increase in mean temperature of 2.0 – 3.0 °C by 2090, with 0 – 5% less precipitation in the Mackenzie area and up to 15 fewer wet days – based on RCP8.5 scenarios (<https://ofcnz.niwa.co.nz/#/nationalMaps>). This increased temperature and lowered rainfall is likely to increase demand for water use and affect the rate of groundwater recharge available for abstraction.




Figure 6-7 Canterbury region median annual total rainfall<sup>8</sup>




Figure 6-8 Canterbury region median annual temperature<sup>9</sup>

<sup>8</sup> Median annual rainfall for the period 1981 – 2010 from NIWA:  
<https://niwa.co.nz/climate/national-and-regional-climate-maps/canterbury>

<sup>9</sup> Median annual temperature for the period 1981 – 2010 from NIWA:  
<https://niwa.co.nz/climate/national-and-regional-climate-maps/canterbury>

## 6.4 Impacts of Catchment Activities on Water Quality

A summary of catchment impacts is outlined in Table 6-1.

Table 6-1 Catchment impact

Land Use	Percentage Of Catchment Area	Comment
Grassland – Low producing	57%	The low producing grassland in the catchment is not grazed and represents a low risk to the source water. This is due to feral animals which will produce low level of faecal contamination.
Other Land	42%	Predominantly alpine environment. This represents a low risk to the source water with low level of faecal contamination expected from birds and feral animals.
Wetland – Open water and Wetland – Vegetated non forest	<1%	This small area of wetland represents a low risk to the source water with low level of faecal contamination expected from birds and feral animals.

## 6.5 Cyanobacteria

A cyanobacteria risk assessment found that there is a moderate to high risk of cyanobacteria formation (WSP, 2022). The assessment recommended that MDC:

- Monitors the source water for phosphorus, turbidity, pH and temperature quarterly during the year and monthly over summer period.
- Monitors for presence of cyanobacteria in Fork Stream upstream of the Tekapo infiltration galleries over the period from November to March.

As there is a moderate risk of cyanobacteria formation, a cyanobacteria/cyanotoxin response plan will need to be prepared (Rule S3.8 in the Drinking Water Quality Assurance Rules).

## 6.6 Protozoa Log Removal Level

Section 5.2.1.2 of DWSNZ says, “The default requirement for protozoa in surface waters is 3-log inactivation or removal. Drinking water safety plans include an assessment of the catchment; if this indicates that 4-log credits may be required, Cryptosporidium monitoring is needed. Cryptosporidium monitoring is not required if the water supplier elects to provide 4-log credits.”

Based on the low risks of microbial contamination identified in the catchment, a treatment process which provides 3-log protozoal removal is considered appropriate.

## 6.7 Values Identified by Local Authorities Under the National Policy Statement for Freshwater Management

A summary of the national requirements for the National Policy Statement for Freshwater Management 2020 (NPSFM) and the relevant objectives and policies of the Canterbury Land and Water Regional Plan (LWRP) as they relate to this water supply are included in Appendix A.

### 6.7.1 Tekapo/Takapō Infiltration Gallery

The Takapō/Tekapo water take is from an infiltration gallery near Fork Stream, and as such affects both groundwater and surface water sources. Fork Stream then feeds into the Tekapo River downstream of the water take.



The drinking water supply protection area is shown in Figure 6-3.

The LWRP (including Plan Change 7 Decisions dated 17 November 2021) contains the following notations for Tekapo/Takapō in the vicinity of the drinking water takes:

- Schedule 1: Community Drinking-water Protection Zone
- Tekapo groundwater quality zone
- Nearby is a tributary that flows into the Tekapo River. The tributary surface water body is an Alpine Upland Water Quality Management Class, while Tekapo River surface water body is a Lake-fed Upland Water Management Class.
- Nutrient Allocation Zone – At risk classification

It needs to be noted the LWRP does not map wetlands of importance. However, the Department of Conservation Wetlands of Representative Importance layer in Canterbury Maps contains a notation in the vicinity of the drinking water takes as shown in Figure 6-9.




Figure 6-9 Wetlands of representative importance

### 6.7.2 Arowhenua Engagement

A meeting was held with Arowhenua on 22 June 2022 to discuss the values of the water bodies that Mackenzie District Council uses for its water supply. Arowhenua advised that Fork Stream forms part of the extensive network of kāinga mahinga kai located throughout Te Manahuna that was renowned for tuna and weka

### 6.7.3 Implications of the values

A source water risk management plan must have regard to any values identified by local authorities under the NPSFM that a supplier uses as a source of drinking water. The NPSFM contains policy direction related to protecting the values of freshwater that are to be implemented by the Regional Council through the PNRP. Values that have been identified for the Takapō/Tekapo water source are summarised in Table 6-2.

Table 6-2 Values Identified for the water sources

	Cultural	Contact Recreation	Biodiversity Values	Ecosystem Values	Trout Fishery and Spawning	Wetlands
Fork Stream	✓					✓
Unidentified shallow aquifer						

‘Having regard to’ requires consideration of the values and what they seek to protect alongside other factors. In developing the source water risk management plan regard has been given to the values by understanding of the catchment from which drinking water is taken.

Resource Consent CRC971414 for the water take was granted in 1998 (see Figure 6-10). It requires monitoring of groundwater levels, outflow from the Fork Stream Wetland and flows in Fork Stream at Balmoral.

- 1 The combined rate at which water is taken from infiltration gallery I37/0008, 150 metres long, two metres diameter and six metres deep, and I37/0009, four metres diameter and six metres deep, shall not exceed 40 litres per second.
- 2 (a) Monitoring of groundwater levels, outflow from the Fork Stream Wetland, and flows in Fork Stream at Balmoral, shall be undertaken in accordance with the details submitted in this consent application.(b) Records of all monitoring undertaken in accordance with condition (2a) of this consent shall be kept, and a copy of the records shall be forwarded to the Canterbury Regional Council every six months, or on request.
- 3 Monitoring of changes in spatial extent and nature of the vegetation of the Fork Stream Wetland shall be undertaken in accordance with the report prepared by Dr Trevor Partridge attached to this consent, and shall include:(a) baseline monitoring before the commencement of works authorised by consent CRC971413; and(b) annual monitoring of the four transects by a suitably qualified person during the period 1 February to 31 March for the first five years, and thereafter at the same or a lesser frequency, as determined by the Canterbury Regional Council.(c) a record of the monitoring, a copy of which shall be provided to the Canterbury Regional Council before 30 April each year, or on request.
- 4 The hours and rate at which water is taken shall be continuously measured to within an accuracy of 10 percent, and shall be recorded continuously. A copy of the records shall be forwarded to the Canterbury Regional Council at the same time as the records required by condition (2) of this consent.
- 5 The Canterbury Regional Council may annually, on the last working day of July, serve notice of its intention to review the conditions of this consent for the purposes of:(a) dealing with any adverse effect on the environment which may arise from the exercise of the consent and which it is appropriate to deal with at a later stage; or(b) complying with the requirements of a relevant rule in an operative regional plan.(c) varying the frequency or methodology of the monitoring programmes specified in conditions (2) and (3), should any significant changes in water levels, flows or vegetation in Fork Stream Wetland be detected, that have arisen from the exercise of this consent.
- 6 Charges, set in accordance with section 36 of the Resource Management Act 1991, shall be paid to the Regional Council for the carrying out of its functions in relation to the administration, monitoring and supervision of resource consents and for the carrying out of its functions under section 35 of the Act.

Figure 6-10 Takapō/Tekapo water take resource consent conditions. Resource CRC971414

## 7 Existing Preventive Measures and Barriers to Contamination

### 7.1 Introduction

Multi-barrier risk management is considered the best practice approach to supply drinking water as it identifies barriers that prevent contamination from entering the water at every step from catchment to tap. The quality of water supplied by the Council to consumers is secured through the use of multiple barriers to the entry of contaminants. Barriers to contamination considered in this plan extend from catchment to the end supply to consumers.

The four types of barriers are:

- Preventing hazards entering the raw water
- Removing particles, pathogens, and chemical and radiological hazards from the water
- Killing or inactivating pathogens in the water
- Maintaining the quality of the water in the distribution system.

In addition to considering barriers at each step in the physical supply chain (source, treatment, distribution, reticulation) barriers have also been considered for each step in the supply management process.

### 7.2 Preventing Hazards Entering the Raw Water

The protected catchment and the infiltration gallery provide a partial barrier to microbial contaminants, turbidity and acute chemical contaminants. Analysis of the raw water has not shown any contaminants of concern.

### 7.3 Removing Particles, Pathogens, and Chemical and Radiological Hazards from the Water

Raw water is sourced from an infiltration gallery adjacent to Fork Stream. The turbidity of raw water is consistently low at approximately 0.07 NTU. The consistently high water quality means that there is no need for a treatment process to remove particles from the water.

The Tekapo water treatment plant uses chlorination and UV disinfection. This is considered to provide a full barrier to microbial contamination.

As there are no known chemical or radiological hazards present, there is no need to remove these hazards from the water.

### 7.4 Killing or Inactivating Pathogens in the Water

Disinfection is used to eliminate the risk of bacteria and viruses contaminating the water supply. The water supply is disinfected with UV disinfection which provides 3-log inactivation of protozoa.

This is considered to provide a complete barrier to bacteria, protozoa and viruses in the water.

### 7.5 Maintaining the Quality of the Water in the Distribution System

The treated water reservoir is covered to prevent ingress of rainwater or contaminants. The reservoir has been recently relined, and pipe network is in generally good condition.

Sodium hypochlorite is dosed followed by UV disinfection. The water supply targets a free available chlorine residual of 0.3 – 0.4 mg/L in water leaving the UV treatment plant and 0.3 mg/L in the distribution zone. The chlorine residual in the network provides a partial barrier to re-contamination.



Backflow prevention is a crucial part of maintaining the quality of water in the distribution system. Backflow prevention is required for all high and medium hazard connections to prevent contaminants entering the distribution network. There is an improvement action to install backflow prevention devices at the boundary of properties with high and medium hazard activities (see Section 8.1).

It is considered that the chlorine residual, the good condition of the distribution infrastructure and continuous positive pressure in the reticulation provides a partial barrier to maintain the quality of water in the distribution system. Once backflow prevention is in place, this will be a complete barrier.

## 7.6 Additional Mitigation Measures

In addition to the considerations above, the following measures also assist in providing barriers in the distribution network:

MDC employs a dedicated maintenance contractor to provide services to the water supply network. Whitestone is the only contractor licensed by MDC that is permitted to work on the network and must follow Standard Operating Procedures and best-practice approaches. Other contractors may be permitted to work on the network with Council approval.

The option of providing water via tanker is a fall-back preventive measure to ensure the community continues to be provided with safe drinking water in the event of source, treatment or distribution quality and/or quantity issues. MDC can engage Cone Peak Farms Ltd for water delivery services in case of emergencies, who deliver potable water from Twizel and are a registered water carrier.

## 7.7 Summary of Existing Preventive Measures

The existing preventive measures for hazards and hazardous events are listed in the risk assessment table.

## 7.8 Effectiveness of Preventive Measures

Based on the information presented in the risk assessment table (Appendix A) and in Sections 7.2 to Section 7.6, it is considered that there are adequate preventive measures in place that contribute to the effectiveness of three of the four barrier types.

Table 7-1 Summary of effectiveness of preventive measures

Type of Barrier	Statement on Effectiveness of Existing Preventive Measures
Preventing hazards entering the raw water	The protected catchment significantly reduces the risk of hazards entering the raw water. Comprehensive source water quality monitoring shows that there are no contaminants of concern.
Removing particles, pathogens, and chemical and radiological hazards from the water	Source water is consistently high quality with low turbidity. Filtration through the infiltration gallery and chlorination demonstrates an effective barrier to particles is in place.
Killing or inactivating pathogens in the water	UV disinfection within specified ranges and no <i>E. coli</i> detected at the treatment plant demonstrates an effective treatment barrier is in place.
Maintaining the quality of the water in the distribution system	<p>FAC levels occasionally drop below the target at the UV plant. <i>E. coli</i> was detected once in the reticulation in the past five years. The transgression was attributed to the sampling process.</p> <p>An additional barrier in the reticulation is needed to reduce the risk to an acceptable level. An improvement to add backflow prevention devices to high and medium risk connections is included in this drinking water safety plan which addresses the unacceptable risk.</p>

Notwithstanding the above statement Council has identified several areas for improvement which are outlined in Section 8.

## 8 Identification of Additional Preventive Measures and Improvement Plan

### 8.1 Improvements to Address Unacceptable Risks

The risk assessment table in Appendix A includes an assessment of each risk's acceptability in light of the associated uncertainty. An improvement plan has been developed that includes several improvements which will address the unacceptable risks and help deliver a safer and more robust water supply.

Table 8-1 describes improvement actions discussed in the risk workshop, to mitigate risks deemed unacceptable. Those items that address a high risk are assigned the highest priority (1) and those that address a medium risk are the next priority (2).

The responsibility for ensuring progress on the improvement item, the timeframe for the improvement, and estimated cost are also included in the table. To ensure that the work is undertaken, responsibilities have been assigned to the relevant Council staff. Roles and responsibilities are likely to change and therefore are required to be checked as part of the annual internal drinking water safety plan review process. Senior management has endorsed these improvements approving the full drinking water safety plan, reflected in the signatures provided on page 2.

Table 8-1 Improvement actions - unacceptable risks

Improvement Number	Improvement Action	Mitigates Risk No(s)	Person Responsible	Estimated Cost	Timeframe	Priority 1 = High 2 = Medium 3 = low
1	Monitor disinfection by-products (6-monthly monitoring has commenced)	2.05	3 Waters Manager	\$5,000	End of 2022	1
2	<ul style="list-style-type: none"> <li>• Undertake survey of commercial customers to determine backflow hazard (complete)</li> <li>• Install backflow prevention devices on high and medium hazard connections</li> <li>• Test all testable backflow prevention devices annually</li> <li>• Create and maintain backflow register</li> <li>• Undertake assessment of backflow risk for residential connections</li> </ul>	4.08	Engineering Manager and 3 Waters Manager	\$5,000	End June 2023	1

## 8.2 Potential Additional Improvements

The Council continuously works to improve water supply delivery and during the risk workshops additional areas where improvements could be implemented were identified (see Table 8-2). These items have a lower priority than those in Table 8-1 and will be addressed when and if staff resources and funding are available. The timeframes presented are estimates only.

Table 8-2 Additional improvement actions

Action Number	Improvement Action	Mitigates Risk No(s)	Person Responsible	Estimated Cost	Timeframe	Priority 1 = High 2 = Medium 3 = Low
3	<ul style="list-style-type: none"> <li>Monitor the source water for phosphorus, turbidity, pH and temperature quarterly during the year and monthly over summer period.</li> <li>Monitor for presence of cyanobacteria in Fork Stream upstream of the Tekapo infiltration galleries over the period from November to March.</li> <li>Prepare a cyanobacteria/cyanotoxin response plan.</li> </ul>	1.06	3 Waters Manager	\$10,000	End 2023	2
4	Increase monitoring at UV treatment plant so that the maximum interval between data records is 1 minute for: <ul style="list-style-type: none"> <li>Flow rate at each reactor</li> <li>UV intensity</li> <li>Turbidity</li> </ul>	2.08 2.09 2.10 2.11	3 Waters Manager	Staff time	14 November 2022	3
5	Install permanent generator at water treatment plant	2.11	3 Waters Manager	\$5,000	End 2026 (LTP)	3
6	Update the SOP that describes the calibration and maintenance requirements for the Takapō/Tekapo drinking water supply	All treatment risks	Whitestone Contracting	Staff time	End March 2023	3
7	Construct an additional reservoir on the eastern side of Tekapo River – Feasibility Study	3.04 3.05	3 Waters Manager	\$400k	End 2026 (LTP)	3
8	Install an additional supply main from reservoir to town – Feasibility Study	4.01	3 Waters Manager	\$400k	End 2026 (LTP)	3

Action Number	Improvement Action	Mitigates Risk No(s)	Person Responsible	Estimated Cost	Timeframe	Priority 1 = High 2 = Medium 3 = Low
9	Implement water metering (across all schemes)	4.09	3 Waters Manager	\$1M (across all schemes)	End 2026	3
10	Implement alkalinity correction to meet guideline values	4.12	3 Waters Manager	\$20,000	End 2023	3
11	Incorporate dedicated sampling points in the reticulation network	5.02	3 Waters Manager	\$10,000	End 2024	3
12	Review operations and maintenance manuals (all schemes)	5.04	3 Waters Manager	Staff time	End 2022, annually	3
13	Develop emergency response plans and business continuity plans (all schemes)	5.10	Engineering Manager	Staff time	June 2023	3

## 9 Operational Procedures

### 9.1 Operational Staff Training

MDC and Whitestone Contracting Ltd staff managing and operating the Tekapo/Takapō drinking water supply have the following training certificates and qualifications (Table 9-1).

Table 9-1 Staff training certificates and qualifications

Role / Position	Training Certificate	Qualification
Water Supply Operator - Whitestone Contracting Ltd	Drinking Water - Water Treatment - Level 4	National Certificate
Water Supply Operator - Whitestone Contracting Ltd	Drinking Water - Water Treatment - Level 4	National Certificate (currently training)
3 Waters Manager - Mackenzie District Council	Drinking Water - Water Treatment - Level 4 & Level 5	Training completed but qualification / certificate not held

### 9.2 Operations and Maintenance Manual

The Tekapo/Takapō Water Operational Manual describes how the Tekapo/Takapō drinking water supply should be operated and maintained. The manual was prepared, reviewed, and approved in 2019. There is a potential additional improvement action to review and update the existing Operations Manual on a regular basis to maintain its currency.

### 9.3 Standard Operating Procedures

Whitestone Contracting Ltd have a list of standard operating procedures (SOPs) for Tekapo/Takapō water treatment plant and for potable water sampling techniques. The Operations and Maintenance Management Procedures detail routine maintenance required at the treatment plant, pump stations, and reticulation and whose responsibility it is. This also specifies training and certificates required from maintenance staff, and the programmed maintenance checks in place.

The SOP for the water treatment plant details the responsibility of the operator, health and safety requirements, and processes and timeframes for checks. A list of SOPs for the Tekapo/Takapō water treatment plant is provided in Table 9-2.

Table 9-2 Tekapo/Takapō water treatment plant standard operating procedures

Procedure No.	Version No.	Operations Instructions
SOP-OPS-007	Revision 03	Chlorine Handling & Storage 1
SOP-OPS-008	Revision 04	Potable Water Sample Testing
SOP-OPS-034	Revision 03	Pump Maintenance

Document/version control is in place to ensure SOPs are reviewed every two years. The document revision number, approval date, review date and authorising party are documented in the SOP header. SOPs are authorised by the Whitestone Contracting Ltd Chief Executive Officer.

The following SOPs have been added to the improvement programme:

- Maintenance of UV disinfection units
- UV sensor calibration
- Reticulation maintenance and replacement
- Contamination event response
- Installing and testing backflow prevention devices.



## 9.4 Operations and Maintenance Activities

There is a list of monitoring and inspections that the maintenance contractor needs to conduct daily, weekly, and monthly in the Tekapo/Takapō Water Operational Manual. Maintenance tasks that need to be undertaken bi-monthly, six-monthly, and annually are also listed. The Tekapo/Takapō Water Data Recording Sheet template is in Appendix A of the operational manual.

Regular operations and maintenance activities are scheduled by MDC for Whitestone Contracting Ltd. These activities are recorded and saved in Laserfiche.

## 9.5 Operational Monitoring and Inspection

The monitoring and inspection plans are described in the maintenance contract MDC have in place with Whitestone Contracting Ltd. The monitoring and inspection plans for the Tekapo/Takapō water supply are:

- Part 9.2.1 – Levels of Service
- Part 9.3 – Monitoring Inspection Duties
- Part 9.7 – Routine Maintenance.

These are saved in Laserfiche (MDC’s document management system). Geoff Horler and Bernie Haar (former MDC Engineering Manager) were involved in revising the existing contract in 2019/2020.

Water quality monitoring records are stored in Council’s SCADA system (for parameters measured continuously) and in Laserfiche (for grab samples e.g., reticulation monitoring data). Historical data previously stored in Drinking Water Online is now stored in Laserfiche as Taumata Arowai’s Hinekōrako replaced Drinking Water Online on 30 November 2021. A more limited set of data is reported in Hinekōrako. MDC uses Lutra Infrastructure Data for storing its water quality data.

Records of contractor inspections are supplied to MDC weekly and stored in Laserfiche.

## 9.6 Critical Control Points

A Critical Control Point (CCP) is a point, step or procedure at which controls can be applied and a drinking water safety hazard can be prevented, eliminated or reduced to acceptable (critical) levels. The most common critical control points in a water supply where water suppliers designate critical limits, are disinfection and filtration processes.




Figure 9-1 Flowchart to help distinguish a CCP, taken from the Handbook for Preparing Drinking Water Safety Plans

The Tekapo/Takapō water supply has chlorination and UV disinfection as critical control points over which process controls can be made.

Table 9-3 Critical points and critical control points

	Critical Point	Description
1	Infiltration Gallery	Possible access point for contamination due to source water contamination. Abstraction through the infiltration gallery reduces turbidity and protozoa load.
2	<b>Critical Control Point</b> Chlorine dosing	Chlorination controls bacterial and viral pathogens and failure reduces the number of treatment barriers and the residual disinfectant provided in the distribution zone. Overdosing may exceed the chemical MAV.
3	<b>Critical Control Point</b> UV disinfection	UV reactors disinfect the water of all micro-organisms and failure removes the only protozoa barrier in the treatment process.
4	Treated Water Storage	Possible point for microbiological contamination. The reservoir is covered and has vermin protection to prevent recontamination.
5	Distribution system	Possible recontamination of the treated water in the distribution system. A chlorine residual provides a partial barrier to recontamination throughout the distribution system. Possible access point for contamination due to backflow.

### 9.6.1 Chlorine Disinfection – CCP3

Chlorine disinfection provides a secondary **disinfection CCP** to inactivate bacterial and viral pathogens that may have entered upstream in the system.

This also provides a **residual disinfection quality control point** to help inactivate pathogens entering downstream of the dosing point.

Table 9-4 Tekapo/Takapō chlorine disinfection critical control point process objectives

OPERATIONAL DAY-TODAY MONITORING OF CONTROL PROCESSES	
What	FAC concentration
When	Monitored weekly at the treatment plant and daily in the distribution zone. Continuously monitored online at the treatment plant.
Where	Designated sampling point in the distribution zone. Prior to the treated water reservoir.
How	Portable spectrophotometer for sampling. Continuous online monitoring analysers with alarms to the operators if measurement approaches designated parameters.
Who	Sampling undertaken by the duty operator. Results are telemetered to the duty operator.
Records	All data is recorded digitally to the Mackenzie District Council SCADA system and Laserfiche.
<i>Process performance criteria at the operational monitoring point.</i>	<i>Correction required if performance criteria are not met.</i>
Target Range	<ul style="list-style-type: none"> <li>&gt; 0.3 mg/L in water leaving the treatment plant</li> <li>&gt; 0.2 mg/L in the distribution zone</li> </ul> <ul style="list-style-type: none"> <li>Perform routine plant/supply assessment, checks, calibration, and maintenance.</li> <li>Chlorine dose is automatically controlled by chlorine dosing control system, controlled by a FAC setpoint reading on the post-filtration chlorine analyser, set by the Operator.</li> <li>Operator to check FAC concentration and if necessary, change dosing rate to ensure the target range is maintained.</li> <li>Operator to perform routine treatment plant and chemical supply assessment and checks.</li> </ul>
Action Limits	<ul style="list-style-type: none"> <li>Low limit: 0.2 mg/L – 0.3 mg/L in water leaving the treatment plant &lt;0.2 mg/L in the distribution zone</li> <li>High Limit: 2.0 mg/L – 5.0 mg/L in water leaving the treatment plant</li> </ul> <ul style="list-style-type: none"> <li>Chlorine Low Alarm, or Chlorine High Alarm are initiated, going to SCADA and Operator pager system.</li> <li>Operator to visit site and check calibration of chlorine analyser and pH meter.</li> <li>Operator to check supplies of chlorine gas and dosing systems.</li> <li>Operator to adjust chlorine gas dosing to within target limits.</li> <li>Operator to record cause of failure and corrective steps taken.</li> <li>Operator to advise 3 Waters Manager of incident and corrective actions taken.</li> </ul>
Critical Limits	<ul style="list-style-type: none"> <li>Low Limit: &lt; 0.2 mg/L mg/L in water leaving the treatment plant</li> <li>&lt; 0.2 mg/L in the distribution zone</li> <li>High Limit: &gt;5.0 mg/L in water leaving the treatment plant</li> </ul> <p>Continue with Action Limit response and:</p> <ul style="list-style-type: none"> <li>Operator to go to site to investigate the cause of the problem and rectify.</li> <li>Operator to notify the 3 Waters Manager and Engineering Manager.</li> <li>Operator to notify the Taumata Arowai Compliance Officer.</li> <li>If FAC in water from treated water storage reservoir &lt; 0.2 mg/L, discuss with Taumata Arowai Compliance Officer about the need to issue a boil water notice and/or provision of tankered water.</li> <li>Operator to complete an investigation into the failure and record the results of the investigation and any improvement actions.</li> </ul>

### 9.6.2 UV Disinfection – CCP2

UV treatment provides the primary **disinfection CCP** to inactivate bacterial, viral and protozoan pathogens that may have entered the water supply upstream of the system.

Table 9-5 Tekapo/Takapō UV critical control point process objectives

OPERATIONAL DAY-TODAY MONITORING OF CONTROL PROCESSES		
What	UV intensity and UV transmittance.	
When	UV intensity is continuously monitored. UV transmittance is measured weekly.	
Where	In the treatment plant (at the UV reactor)	
How	Continuous online monitoring analysers with alarms to the operators.	
Who	Results are telemetered to the duty operator.	
Records	All data is recorded digitally to the Mackenzie District Council SCADA system.	
Process performance criteria at the operational monitoring point.	Correction required if performance criteria are not met.	
Target Range	UV intensity $\geq 48$ mJ/cm <sup>2</sup> UV transmittance $> 98\%$	Normal operating range for UV disinfection. No action required. Conduct normal checks/calibrations on reactor.
Action Limits	UV intensity 40 mJ/cm <sup>2</sup> – 48 mJ/cm <sup>2</sup> UV transmittance 95% – 98%	If there is a UV fault, on-call operator receives an alarm. <ul style="list-style-type: none"> <li>Operator to visit the plant to check situation and repair/rectify. UV visual alarms at plant, lights are displayed to diagnose the fault type.</li> <li>Record cause of failure and corrective steps taken.</li> </ul>
Critical Limits	UV intensity $< 40$ mJ/cm <sup>2</sup> UV transmittance $< 95\%$	Continue with Action Limit response and: <ul style="list-style-type: none"> <li>Duty Supervisor notifies Taumata Arowai if inadequately treated water needs to be supplied or has been supplied to the community and considers with the Taumata Arowai Compliance Officer the need to issue a boil water notice and/or provide tankered water.</li> <li>The Duty operator notifies the MDC 3 Waters Manager.</li> <li>In consultation with the Taumata Arowai Compliance Officer follow the relevant procedures in DWSNZ Fig 5.2 (plant).</li> <li>Operator to complete an investigation into the failure and record the results of the investigation and any improvement actions.</li> </ul>

## 10 Verification Monitoring Programme

The effectiveness of the drinking water safety plan is determined by verification monitoring, which assesses the drinking water quality at the point at which it is supplied to a consumer's property. The assessment makes use of water quality testing and consumer complaints. The latter provides an important source of information about the aesthetic properties of the water.

### 10.1 Drinking Water Quality Compliance Monitoring

Compliance monitoring requirements for the Tekapo/Takapō drinking water supply are flow based. Flow data is sent directly to Taumata Arowai and ECan from the SCADA system. Compliance monitoring results are stored in SCADA, on the MDC computer servers (Laserfiche) and Hinekōrako.

### 10.2 Microbial Reduction from Water Treatment Processes

This section describes the measures in place to comply with DWSNZ.

#### 10.2.1 Protozoal Compliance

Protozoal compliance is able to be achieved through UV disinfection (3-log protozoa inactivation). Bacterial compliance is able to be achieved throughout the treatment process.

The water leaving the Tekapo/Takapō water treatment plant is monitored in accordance with bacterial compliance criterion 1 in section 4.2 of the DWSNZ.

The water in the distribution system is monitored in accordance with compliance criterion 6A in section 4.3.1 of the DWSNZ.

#### 10.2.2 Treated Water Quality

Table 10-1 shows the required water quality standards and where this is sampled.

Table 10-1 Treated water quality specifications

Parameter	Compliance Range	Sampling Point
<i>E. coli</i>	< 1 per 100 mL	WTP post treatment, and Hamilton Drive sampling point
Treated water turbidity	< 2.0 NTU	WTP post treatment, and Hamilton Drive sampling point
UV intensity	≥ 40 mJ/cm <sup>2</sup>	WTP post treatment
UV transmittance	98%	WTP post treatment
Treated water FAC target	0.2 mg/L	WTP post treatment, and Hamilton Drive sampling point

#### 10.2.3 Compliance with DWSNZ - Treated Water Quality Monitoring

The Tekapo/Takapō water supply is subject to the various performance criteria detailed in the DWSNZ. The drinking water compliance monitoring regime is carried out in accordance with the requirements set out in DWSNZ. Continuous monitoring data is stored in SCADA as part of the water treatment plant operation.

Table 10-2 provides a summary of the protozoal compliance monitoring with the DWSNZ and Table 10-3 provides a compliance assessment against DWSNZ.

Table 10-2 DWSNZ compliance - protozoal monitoring

Tekapo Treatment Plant	Control	Frequency
Flow	Flow restrictor	Permanent installation
Turbidity	Treated water turbidimeter	Continuous
UV intensity	UVI meter	Continuous
UV transmittance	UVT meter	Weekly
Lamp replacement	Lamp replacement hour meter	Continuous
Lamp outage	Lamp outage sensor	Continuous

Table 10-3 DWSNZ compliance assessment<sup>10</sup>

Standards Compliance Assessed Against	DWSNZ 2005 (revised 2018) Compliance
Bacterial compliance criteria used for water leaving the treatment plant	Criterion 5 not achieved due to insufficient continuous flow monitoring at the UV disinfection unit.
Protozoa log removal requirement for the supply	3-log
Protozoa treatment process	UV Disinfection (3-log protozoa inactivation) not achieved due to insufficient monitoring.
Compliance criteria 6A is used for water in the distribution zone	Yes
Bacterial compliance for water leaving the treatment plant has been achieved for the last 4 quarters	No
Protozoa compliance for water leaving the treatment plant has been achieved for the last 4 quarters	No
Bacterial compliance for water in the distribution zone has been achieved for the last 4 quarters	Yes
P2 determinands allocated to supply	None
Chemical compliance achieved for the last 4 quarters	No
Cyanobacteria identified in the supply	N/A
Cyanobacterial compliance has been achieved for the last 4 quarters	N/A

Annual compliance with the DWSNZ requirements for the Tekapo/Takapō water supply are stored in Hinekōrako. Compliance survey results for the past 5 years are shown in Table 10-4.

<sup>10</sup> Annual Drinking Water Compliance Report: 1 July 2021 – 30 June 2022 (WSP, 2022)

Table 10-4 Annual Health Act compliance survey results

Compliance Survey	2017/18	2018/19	2019/20	2020/21	2021/22
Supplier Complied with Duty to:					
Provide Drinking Water (69S)	Yes	Yes	Yes	Yes	Yes
Take Steps to Protect Source (69U)	Yes	Yes	Yes	Yes	Yes
Duty to Monitor Drinking Water (69Y)	Yes	Yes	Yes	Yes	Yes
Duty to Prepare and Implement water safety plan (69Z)	-	-	Yes	Yes	Yes
Keep Records and make them Available (69ZD)	Yes	Yes	Yes	Yes	Yes
Investigate Complaints (69ZE)	Yes	Yes	Yes	Yes	Yes
Duty to Take Remedial Actions (69ZF)	No	-	Yes	Yes	Yes
Bacterial Compliance	Yes	Yes	Yes	No	No
Protozoal Compliance	No	No	No	No	No

Note: The sections referred to in this table relate to the Part 2A of the Health Act 1956, which has now been replaced by the Water Services Act.

The compliance report noted that protozoal compliance with the DWSNZ was not met due to insufficient monitoring at the UV disinfection unit. Bacterial compliance at the treatment plant was not achieved due to insufficient pH data, and elevated turbidity on one occasion. Continuous pH monitoring has since been implemented.

## 10.3 Consumer Satisfaction

### 10.3.1 Customer Satisfaction

MDC carries out a 'Residents Opinion Survey' each year, to seek feedback from residents on their satisfaction with services like water supplies, roads, community facilities and rubbish collection. Satisfaction surveys have been carried out annually every year for over 10 years. The information is gathered to provide a robust measure of satisfaction with service delivery, determine performance drivers and identify the best opportunities for improving performance, and to measure progress towards long-term objectives.

The most recent survey (2020) was conducted via telephone interviews with resident and non-resident ratepayers that reside in the Mackenzie district. Key findings of the survey were:

- 80% of respondents were satisfied with the water supply and quality.
- The performance target of 80% satisfaction was met.
- Satisfaction levels were similar to the previous year (83% in 2019).
- Concerns causing dissatisfaction were in relation to chlorine content, poor taste/appearance/quality content and water supply issues.

Data collection was randomised to ensure the sample included a range of respondents based on age, location, and gender, with a quota system in place to ensure the sample was representative of the population in line with 2018 Census results.

Residents are also encouraged to provide feedback through the Council's Consultation webpage or in person at the customer services desk.

Responses from the Community Satisfaction Survey form part of the results for Council's Annual Report.



### 10.3.2 *Customer Service Requests and Complaints*

Customers are able to lodge service requests or notify the Council of water problems at any time via:

- Customer Contact Centre, by phone or in person. This is the Council's main number, and it is available in the White Pages or on the Council's website under 'Contact Us'.
- Online via the 'Contact us', 'Ask a question' or the 'Report an issue' forms, these forms are available on the Council's website under the 'Contact Us' webpage.

Staff in the Customer Contact Centre record all calls, complaints, and letters. Service requests are tracked in MAGIQ Software called NCS. Anything that requires an action is logged and forwarded to the appropriate team for resolution. The time taken to respond and resolve the issue is recorded.

## 10.4 **Short-term Evaluation of Results**

Assessment of the performance of this drinking water safety plan is undertaken annually. This includes a review of the operational and verification monitoring and inspection results. If necessary, the drinking water safety plan will be updated in response to this annual review. This provides an early warning for any problems that may occur and allows MDC to monitor how well the plan and activities are working.

MDC holds weekly meetings with the maintenance contractor to discuss compliance data and incidents. Critical issues are reported to MDC on the day of occurrence.

Short term evaluation of results is undertaken monthly by the Council's water team as part of a routine reporting cycle to identify trends or issues at the supply and confirm whether compliance requirements have been met.

The level of compliance of the applicable water supplies is reported to the Community Boards bi-monthly.

## 11 Management of Incidents and Emergencies

### 11.1 Previous Incidents and Emergencies

The Takapō/Tekapo drinking water supply has never achieved protozoal compliance with the DWSNZ. There is an improvement action in Section 8.1 to address this.

*E. coli* has been detected twice in the distribution zone in the last five years during the 2020/2021 monitoring period. Following the incident, a transgression report was submitted, and the remedial actions considered appropriate by the Drinking Water Assessor. A temporary boil water notice was issued. Due to the transgression, the supply failed to meet bacterial compliance between 1 July 2020 to 30 June 2021.

### 11.2 Incident and Emergency Response Plan

#### 11.2.1 Levels of emergency

Defining and assigning a level of emergency to each type of possible incident/emergency assists with clear internal communication of the hazard threat level.

Table 11-1 defines the emergency descriptors used by MDC during incident/emergency responses. Each emergency response plan indicates the range of emergency levels that may apply, which will depend on the specific event.

Table 11-1 Emergency / incident level descriptor

Incident/emergency level	Description of level
Level 5	Widespread outbreak of waterborne disease
	Declared civil defence natural disaster
	Water supply unable to be maintained
	Gross exceedance of one or more chemical MAVs (e.g., more than 5x MAV, including cyanotoxins)
Level 4	<i>E. coli</i> >10 cfu/100 mL or any pathogen detected at the treatment plant or in reticulation
	Failure of infrastructure resulting in water outages for consumers lasting > 8 hours
	Alert from District Health Board that surveillance information suggests cases of illness in the community are drinking water related
Level 3	Detection of <i>E. coli</i> (<10 cfu/100 mL) in reticulation
	Exceedance of one or more chemical MAVs
Level 2	Preventive measure failure in combination with corrective action failure
	One or more chemicals at greater than 50% of MAV
Level 1	Exceedance of a DWSNZ aesthetic guideline (GV), possibly resulting in customer complaints
	Water restrictions required to enable supply continuity

### 11.2.2 Emergency Response Plan

MDC is a member of the Canterbury Region CDEM Group, which includes all local authorities in the Canterbury Region. The Canterbury Region CDEM Group is responsible for developing the recovery arrangements for their group area. CDEM Groups must state and provide strategic planning for recovery from the hazards and risks identified in their CDEM Group plan.

The Canterbury Region CDEM Group Plan describes how the group will manage and respond to emergencies and sets out the operational arrangements of the group.

MDC does not currently have an emergency response plan in place for the Takapō/Tekapo drinking water supply. There is a potential improvement action in Section to develop an emergency response plan for the plant's operation, principally for response to natural disasters in particular after a major earthquake disrupts the water supply (Level 5 event, see Table 11-1).

### 11.2.3 Incident Response Plan

Implementation of the contingency plan actions when there is an indication of poor water quality is the responsibility of the 3 Waters Manager. These actions are detailed in Table 11-2.

Table 11-2 Takapō/Tekapo water supply incident response plan

Type of Event	Required Actions
<p><b>Microbiological contamination of the abstracted source water</b> (such that treatment is ineffective)</p> <p>Indicators:</p> <ul style="list-style-type: none"> <li>• A contamination event in the surface water catchment may be observed by or reported to MDC staff</li> <li>• High levels of E. coli or total coliforms measured in raw water</li> <li>• E. coli detected in distribution system</li> <li>• Total coliforms &gt; 10 cfu/mL detected in distribution system</li> <li>• Reports of illness in the community</li> </ul>	<ul style="list-style-type: none"> <li>• Notify Taumata Arowai and the 3 Waters Manager.</li> <li>• Issue boil water notice to consumers in conjunction with Taumata Arowai and following Council response plans.</li> <li>• Commence daily E. coli testing at WTP and in the distribution system, use an enumeration test method for both.</li> <li>• Inspect area around the surface water source and surrounding areas to identify source of contamination and rectify problem as quickly as possible.</li> <li>• Super chlorinate the distribution system and flush mains if they contain contaminated water.</li> <li>• Keep customers informed and advise once regular supply is restored.</li> <li>• Consider providing potable drinking water from alternative sources such as bottled water or tankered water.</li> </ul>

Type of Event	Required Actions
<p><b>Elevated turbidity of the abstracted source water and/or high turbidity in water in distribution system</b></p> <p>Indicators:</p> <ul style="list-style-type: none"> <li>Highly turbid water identified in treated water turbidimeter or handheld meter in zone</li> <li>Taste, odour, or visual complaints from consumers</li> </ul>	<ul style="list-style-type: none"> <li>Advise the 3 Waters Manager.</li> <li>Investigate the source of the elevated turbidity.</li> <li>Assess the performance of the treatment processes in place to reduce turbidity at the treatment plant.</li> <li>Where elevated turbidity compromised the plant's ability to adequately disinfect the drinking water, issue a boil water notice to consumers in conjunction with Taumata Arowai and follow Council response plans.</li> <li>Commence daily E. coli testing.</li> <li>Monitor source water turbidity.</li> <li>Keep customers informed and advise once regular supply is restored.</li> </ul>
<p><b>Chemical contamination of source water</b></p> <p>Indicators:</p> <ul style="list-style-type: none"> <li>A contamination event in the surface water catchment observed by or reported to MDC staff.</li> <li>Taste, odour, or visual complaints from consumers</li> <li>Reports of illness in the community</li> </ul>	<ul style="list-style-type: none"> <li>Notify Taumata Arowai and the 3 Waters Manager.</li> <li>Advise consumers not to drink the water supply in conjunction with Taumata Arowai and follow the Council response plans.</li> <li>Assess situation and advise customers regarding use/treatment/disposal of contaminated water.</li> <li>Inspect area around intake to identify source of contamination and rectify problem as quickly as possible.</li> <li>Consider mains isolation to avoid spread of chemical contaminants.</li> <li>Flush mains.</li> <li>Arrange emergency water supply (tankers/bottles) if necessary.</li> <li>Keep customers informed and advise once regular supply is restored.</li> </ul>
<p><b>Insufficient water available for abstraction or loss of ability to take water from the river</b></p> <p>Indicators:</p> <ul style="list-style-type: none"> <li>Observed or reported low abstraction levels</li> <li>Customer complaints</li> </ul>	<ul style="list-style-type: none"> <li>Notify Taumata Arowai and the 3 Waters Manager.</li> <li>Advise customers to conserve water.</li> <li>Implement demand management strategies as outlined in Council response plans as required.</li> <li>Arrange emergency water supply (tankers/bottles) if necessary.</li> <li>Investigate and resolve any intake or pipeline issues.</li> <li>Refer to business continuity plan and emergency response plans once they have been developed, refer Section 8.1 for improvement action.</li> <li>Keep customers informed and advise once regular supply is restored.</li> </ul>

Type of Event	Required Actions
<p><b>E. coli transgression in water in distribution zone</b></p> <p>Indicators:</p> <ul style="list-style-type: none"> <li>• Positive E. coli monitoring results</li> <li>• Reports of illness in the community</li> </ul>	<ul style="list-style-type: none"> <li>• Follow transgression response procedure in DWSNZ.</li> <li>• Notify Taumata Arowai and the 3 Waters Manager.</li> <li>• Commence daily E. coli testing at WTP and in the distribution system, use an enumeration test method for both.</li> <li>• Investigate cause, inspect plant and source.</li> <li>• Take remedial action.</li> <li>• Continue to sample for E. coli until 3 consecutive samples are free of E. coli.</li> <li>• If E. coli is found in any of the repeat samples, consult with Taumata Arowai, intensify remedial action, increase disinfection, issue 'Boil Water' notice.</li> </ul>
<p><b>Inadequate FAC residual in water post treatment enters distribution system</b></p> <p>Indicators:</p> <ul style="list-style-type: none"> <li>• FAC of 0.2 mg/L cannot be maintained in distribution system despite primary corrective actions</li> <li>• Reports of illness in the community</li> <li>• E. coli or total coliforms are detected in the network</li> </ul>	<ul style="list-style-type: none"> <li>• Advise the 3 Waters Manager.</li> <li>• Inspect treatment plant to identify cause of problem and rectify as quickly as possible.</li> <li>• Check quality of chlorine, quantity of chlorine and dosing equipment of levels and faults.</li> <li>• Double check FAC levels in the distribution zone with calibrated equipment.</li> <li>• Investigate contaminant entry at the source and reticulation (including backflow and mains break).</li> <li>• Discuss the need to issue a boil water notice to consumers with Taumata Arowai and follow Council response plans.</li> <li>• Keep customers informed and advise once regular supply is restored.</li> </ul>
<p><b>Excessive FAC residual in water post treatment enters distribution system</b></p> <p>Indicators:</p> <ul style="list-style-type: none"> <li>• FAC &gt;5 mg/L is measured in treated water or in distribution system</li> <li>• Taste and odour complaints from consumers</li> <li>• Reports of illness in the community</li> </ul>	<ul style="list-style-type: none"> <li>• Notify Taumata Arowai and the 3 Waters Manager.</li> <li>• Advise consumers not to drink the water supply in conjunction with Taumata Arowai.</li> <li>• Arrange emergency water supply (tankers/bottles) if necessary.</li> <li>• Assess situation and advise customers regarding use/treatment/disposal of contaminated water.</li> <li>• Identify reason for chlorine limit breach and rectify problem as quickly as possible.</li> <li>• Flush storage tanks and mains and advise consumers to flush taps.</li> <li>• Keep customers informed and advise once regular supply is restored.</li> </ul>
<p><b>Earthquake, flood or other natural disaster</b></p>	<p>Refer to the Canterbury Region Civil Defence Emergency Management Group Plan.</p>

## 12 Documenting and Reporting

### 12.1 Management of Documentation and Records

MDC uses Laserfiche for its document management system. Key documents relating to the water supply system including water quality monitoring reports and maintenance records are stored in Laserfiche. All MDC staff have access to Laserfiche and receive training in its use.

All data that is measured continuously (e.g. treated water turbidity, FAC and pH) is stored in the Council's SCADA system historian, which is accessible to operators and MDC staff.

Lutra Infrastructure Data software is used to store monitoring data via a secure online dashboard. The software stores all SCADA data and directly uploads monitoring results processed by the lab.

Water supply staff are trained in the use of these systems and in how to fill out records properly.

Hinekōrako is used for compliance reporting to Taumata Arowai.

### 12.2 Reporting

Drinking water supply quality, compliance and water supply performance are reported, and publicly available online, to external stakeholders, consumers and other agencies through:

- The Annual Report on Drinking-water Quality by the Ministry of Health. The Council contributed information annually for these reports focussed on bacteriological, protozoal, and chemical compliance with DWSNZ, the status of drinking water safety plans, and meeting legislative requirements. Now that Taumata Arowai has taken over from the Ministry of Health as the regulator, MDC commissioned WSP to prepare the 2021/22 annual compliance report.
- MDC Annual Report: This report is focused on MDC's performance against levels of service and provides insight into the final financial and performance results including DWSNZ compliance and Department of Internal Affairs mandatory non-financial performance measures.
- Compliance updates are reported to the three MDC Community Boards on a monthly basis.
- The Council website and social media platform Facebook are used to communicate boil water notices to the public.
- Resource consent compliance: flow data is sent directly to ECan and Taumata Arowai from SCADA.

## 13 Investigations

### 13.1 Investigative Studies

Investigations can be triggered by an incident or customer complaints. Customer complaints are loaded into the Council's MAGIQ Software NCS system by the Customer Contact Centre to be triaged and actioned by the 3 Waters Manager. All complaints are investigated with the outcome and actions taken recorded once a job is resolved. If there is a cluster of complaints, a wider investigation is undertaken.

MDC is planning investigative studies to assess the unusually high quantity of water consumed by the Twizel and Tekapo water supplies. It is expected that irrigation is a contributing factor. The smart water meter roll out for each supply will help to identify high volume users.

MDC has also engaged WSP to complete the following work during 2022 to address improvement actions, all of which are complete.

- Undertake a cyanobacteria risk assessment for the Takapō/Tekapo drinking water supply
- Develop backflow prevention policy and conduct backflow prevention surveys of commercial properties
- Complete an annual compliance report for the monitoring period between 1 July 2021 and 30 June 2022.

### 13.2 Validation of Equipment, Processes and Practice

Validation collects evidence to establish that preventive measures can perform at the expected level. The regular re-validation of procedures, treatment processes and associated controls ensures their effective operation and adequate control, especially if a process or component has been physically changed or an operational setting changed.

All new equipment is required to be validated by the supplier to confirm that it meets the specifications and is operating correctly.

Routine revalidation of equipment is undertaken by the operators. There is an improvement item to update the SOP that describes the calibration and maintenance requirements for the Takapō/Tekapo drinking water supply.



## 14 Oversight, Review and Continual Improvement

### 14.1 Long-term Evaluation of Results

The Council's long-term evaluation of results is focused on water quality monitoring and system performance.

As well as monitoring for the water take consent for the drinking water supply, the Council monitors and reviews its performance against its levels of service described in the Long Term Plan and Annual Plan. Annual reports identify areas needing immediate attention with a full review every three years as part of the Long Term Plan process which contributes to the funding and development of the water supply network over a ten year period.

The results for water supply levels of service for 2020/21 are summarised in the Mackenzie District Council 2020/21 Annual Report<sup>11</sup>. Of the seven levels of service, three were achieved (fault response times, number of complaints and customer satisfaction). The exceptions were:

Provide safe drinking water:

- 25% of MDC drinking water supplies achieved bacterial compliance in accordance with DWSNZ, compared with a target of  $\geq 95\%$ .
- 0% of MDC drinking water supplies achieved protozoal compliance in accordance with DWSNZ. MDC aims to have 3 of 5 supplies compliant by 2023/2024.

Provide demand management of water supply services:

- The average consumption of drinking water per day per resident within the district was  $1.72 \text{ m}^3$ , compared with a target of  $\leq 1.2 \text{ m}^3$ .
- 26% water loss, compared with a target of  $<25\%$ .

The maintenance contractor is required to report any defects observed during day to day duties. There is an ongoing inspection and maintenance regime under the routine maintenance contract and information recorded is used to inform the condition of assets. Almost 90% of water supply assets are estimated to be in good condition and only 3% assumed to be in poor condition. The overall performance of water supply assets is adequate. The primary concern is achieving DWSNZ compliance.

The Council also records information relating to DWSNZ compliance and transgression information. This was provided annually for the Ministry of Health's annual report on drinking water quality. Historical information on the Takapō/Tekapo water supply can be evaluated from the Ministry of Health's Annual Review of Drinking-water Quality in New Zealand. Reporting is now to Taumata Arowai.

Section 17A of the Local Government Act 2002 requires the Council carry out service delivery reviews. These reviews are a method of determining whether the existing means for delivering a service remain the most efficient, effective, and appropriate means for delivering that service. The most recent review for three waters was carried out in 2019/2020. Reviews are required to be carried out no later than six years following the last review.

### 14.2 Audit of Drinking Water Quality Management

An annual review is undertaken to assess compliance with the DWSNZ and the Water Services Act. Annual reviews of the water safety plan are also completed to ensure improvement actions are implemented within agreed timeframes. Lutra Infrastructure Data software is used to store

---

<sup>11</sup> [https://www.mackenzie.govt.nz/\\_data/assets/pdf\\_file/0005/629474/2020-2021-Annual-Report-Full.pdf](https://www.mackenzie.govt.nz/_data/assets/pdf_file/0005/629474/2020-2021-Annual-Report-Full.pdf)

monitoring data via a secure online dashboard. The software stores all SCADA data and directly uploads monitoring results processed by the lab.

### 14.3 External Audit of Drinking Water Quality Management

External audits of the water supply are undertaken by Taumata Arowai. These were previously undertaken by the Drinking Water Assessor, including a three-yearly review of compliance with the drinking water safety plan. The most recent external audit was carried out in 2020.

Appendix A  
Tekapo/Takapō Drinking  
Water Supply - Risk  
Assessment Table

Supply Element	Hazardous Event			Hazards (associated with the hazardous event)				MAXIMUM Risk (with no preventive measures in place and all barriers failing)						RESIDUAL Risk (with existing preventive measures)								LEVEL OF UNCERTAINTY AND RISK ACCEPTABILITY					
	Event Description	Cause No.	Possible Causes	Bacteria / Viruses	Protozoa	Chemicals / Aesthetics	Disruption to Supply	Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Likelihood	Consequence of the HAZARD	Assessment Rationale - Consequence	MAX L	MAX C	Maximum (unmitigated) Risk	Existing Measures to Identify the Hazard	Existing Preventive measures	Modified Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Modified Likelihood	Modified Consequence of the HAZARD	Assessment Rationale - Modified Consequence	MOD L	MOD C	Residual Risk	Level of Uncertainty	Residual Risk Score	Risk Acceptability	Additional Preventive Measure Required?
Source - Catchment	Microbiological contamination due to surface runoff from catchment, community wastewater systems, dairy effluent ponds or septic tank systems	1.01	Contamination from human or animal activity in catchment, unmonitored permitted activities, consent conditions not followed, or potential impact not considered.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Almost Certain	Assumes no land use controls	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	5	4	Extreme	<ul style="list-style-type: none"> <li>Continuous turbidity, pH and FAC monitoring in treated water</li> <li>SCADA controls and alarms</li> <li>Illness in community</li> </ul>	<ul style="list-style-type: none"> <li>Protected catchment with little human or animal activity</li> <li>Supply is chlorinated and UV disinfected</li> <li>Infiltration gallery set back &gt;50m from stream, providing natural filtration</li> <li>Community drinking water protection zone in Land and Water Regional Plan</li> <li>Treated water storage</li> <li>Use of tankered water</li> <li>rabbit proof fence</li> </ul>	Possible	Protected catchment reduces likelihood	Minor	Treatment reduces consequence	3	2	Medium	Reliable	6	Acceptable	No
Source - Catchment	Chemical contamination from surface runoff containing chemical contaminants from agricultural activities. (e.g. pesticides, fertilisers etc)	1.02	Poor fertiliser / pesticide application practices, landowners in catchment unaware of drinking water catchment area			<input checked="" type="checkbox"/>		Possible	Assumes no land use controls	Major	Potential repeated exceedance of MAV	3	4	High	<ul style="list-style-type: none"> <li>Taste and/or odour complaints</li> <li>Information provided by Ministry of Defence or Dept of Conservation about activities in catchment</li> <li>Source water chemical suite is analysed annually</li> </ul>	<ul style="list-style-type: none"> <li>Protected catchment with little human or animal activity</li> <li>Ministry of Defence are aware that catchment provides water for community water supply</li> <li>DoC own upper catchment</li> <li>Community drinking water protection zone in Land and Water Regional Plan</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Rare	Protected catchment reduces likelihood	Major	PMs don't reduce consequence	1	4	Medium	Reliable	4	Acceptable	No
Source - Catchment	Chemical contamination due to naturally occurring chemical contaminants or land use intensification	1.03	Naturally occurring chemical contaminants from local geology or from land use intensification			<input checked="" type="checkbox"/>		Unlikely		Moderate	Potential widespread aesthetic issues, or repeated breach of maximum acceptable value (MAV)	2	3	Medium	<ul style="list-style-type: none"> <li>Taste and/or odour complaints</li> <li>Source water chemical suite is analysed annually</li> </ul>	<ul style="list-style-type: none"> <li>Protected catchment owned by NZDF and DoC, no land use intensification</li> <li>No contaminants of concern monitored in annual suite</li> <li>Weekly calibration of equipment</li> </ul>	Unlikely	Source water monitoring shows no indication of natural chemical contaminants	Moderate	PMs don't reduce consequence	2	3	Medium	Reliable	6	Acceptable	No
Source - Catchment	Chemical contamination	1.04	Chemical spill in water upstream of infiltration gallery			<input checked="" type="checkbox"/>		Unlikely		Major	Potential repeated exceedance of MAV	2	4	Medium	<ul style="list-style-type: none"> <li>Taste and/or odour complaints</li> <li>Chemical spill is reported</li> </ul>	<ul style="list-style-type: none"> <li>Infiltration gallery is distant from any vehicle tracks and there is no bulk storage of chemicals</li> <li>Protected catchment with little human or animal activity</li> <li>Community drinking water protection zone in Land and Water Regional Plan</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Rare	Protected catchment reduces likelihood	Major	PMs don't reduce consequence	1	4	Medium	Reliable	4	Acceptable	No
Source - Catchment	Increased sediment load in source water	1.05	Heavy rainfall, fire in catchment			<input checked="" type="checkbox"/>		Unlikely		Moderate	Potential widespread aesthetic issues	2	3	Medium	<ul style="list-style-type: none"> <li>Continuous turbidity, pH and FAC monitoring in treated water</li> <li>SCADA controls and alarms</li> <li>Visual observation</li> </ul>	<ul style="list-style-type: none"> <li>Intake through infiltration gallery filters sediment</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Rare	Turbidity is consistently below 1 NTU	Moderate		1	3	Low	Reliable	3	Acceptable	No
Source - Catchment	Cyanotoxin Contamination	1.06	Cyanobacteria growth in source water	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>		Unlikely	No indication of cyanobacteria	Moderate	Potential widespread aesthetic issues	2	3	Medium	<ul style="list-style-type: none"> <li>Taste and/or odour complaints</li> <li>ECan report cyanobacteria in area</li> </ul>	<ul style="list-style-type: none"> <li>Protected catchment with little human or animal activity (no fertiliser, low nitrate levels)</li> <li>Flowing catchment system</li> <li>Use of tankered water</li> </ul>	Rare	Protected catchment reduces likelihood	Moderate	PMs don't reduce consequence	1	3	Low	Estimate	3	Acceptable	No
Source - Catchment	Loss of Supply	1.07	Drought reduces quantity of water that can be abstracted				<input checked="" type="checkbox"/>	Unlikely		Major	Significant compromise of systems and abnormal operation	2	4	Medium	<ul style="list-style-type: none"> <li>Water level in monitoring wells near infiltration gallery are measured monthly</li> <li>Flow meter</li> <li>Reservoir level indicator</li> <li>SCADA controls and alarms</li> <li>Low flows in Fork Stream</li> <li>Prolonged drought or low rainfall conditions</li> </ul>	<ul style="list-style-type: none"> <li>Water restrictions</li> <li>Use of tankered water</li> </ul>	Rare	Consistent water levels measured in monitoring wells	Moderate	PMs don't reduce consequence	1	3	Low	Estimate	3	Acceptable	No
Source - Catchment	Loss of supply	1.08	Consent to take water is not renewed or is declined by the Regional Council or less volume granted				<input checked="" type="checkbox"/>	Possible		Major	Significant compromise of systems and abnormal operation	3	4	High	<ul style="list-style-type: none"> <li>Regional Council raises issues about water consents prior to consent application</li> </ul>	<ul style="list-style-type: none"> <li>Current consent expires in 2033</li> <li>Protected catchment with land owned by Ministry of Defence and Dept of Conservation</li> <li>NPS Freshwater Management prioritises drinking water over other consumptive uses</li> </ul>	Rare		Major	PMs don't reduce consequence	1	4	Medium	Reliable	4	Acceptable	No
Source - Infiltration Gallery	Loss of supply	1.09	Intentional vandalism or accidental damage to infiltration gallery or associated equipment				<input checked="" type="checkbox"/>	Possible		Major	Significant compromise of systems and abnormal operation	3	4	High	<ul style="list-style-type: none"> <li>Flow meter</li> <li>Reservoir level indicator</li> <li>SCADA controls and alarms</li> <li>Obvious signs of damage to structure</li> </ul>	<ul style="list-style-type: none"> <li>Infiltration gallery is below stream bed and is inaccessible</li> <li>Infiltration gallery is well away from public areas, access is through private and NZDF land</li> </ul>	Rare		Moderate		1	3	Low	Reliable	3	Acceptable	No
Source - Infiltration Gallery	Loss of supply due to blocking of infiltration gallery	1.10	Blocking of infiltration gallery with debris, sediment, shifting of river bed after flooding				<input checked="" type="checkbox"/>	Likely		Major	Significant compromise of systems and abnormal operation	4	4	High	<ul style="list-style-type: none"> <li>Flow meter</li> <li>Reservoir level indicator</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Infiltration gallery is located in an area with free draining gravels set back from stream</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Unlikely	Blocking of infiltration gallery has not been a problem since it was installed in 1999	Minor	Manageable disruption to normal operation if unblocked or alternative intake with reservoir storage	2	2	Low	Estimate	4	Acceptable	No
Source - Raw Water Pipeline	Loss of Supply	1.11	Raw water pipeline failure between intake and treatment plant Damage to pipeline by landowner/contractor				<input checked="" type="checkbox"/>	Possible		Major	Significant compromise of systems and abnormal operation	3	4	High	<ul style="list-style-type: none"> <li>Flow meter</li> <li>Visual inspection</li> <li>Customer complaints</li> <li>SCADA controls and alarms</li> <li>Condition and type of materials of pipeline</li> <li>Records of pipeline failures and repairs</li> </ul>	<ul style="list-style-type: none"> <li>Pipeline is PVC and is in excellent condition</li> <li>Deep and not in road reserve, location known by farmer</li> <li>Most breaks can be repaired quickly by maintenance contractor</li> <li>Maintenance contract requires rapid response to repair pipe failures (KPIs)</li> <li>Easement over raw water pipeline route where it crosses private property</li> <li>Pipeline locations published online on Canterbury Maps</li> <li>Spare pipes and couplings stored at contractor yard</li> <li>Treated water storage</li> <li>Water use restrictions</li> <li>Use of tankered water</li> </ul>	Unlikely	Pipe is in excellent condition and location is known and published online	Moderate	Significant (but manageable) disruption to normal operation	2	3	Medium	Reliable	6	Acceptable	No
Source - Raw Water Pipeline	Inadequate quantity of water supplied	1.12	Size of raw water pipeline is inadequate				<input checked="" type="checkbox"/>	Possible		Moderate	Significant disruption to normal operation	3	3	Medium	<ul style="list-style-type: none"> <li>Flow meter</li> <li>Hydraulic calculations, modelling</li> <li>Customer complaints</li> <li>SCADA controls and alarms</li> <li>Condition and type of materials of pipeline</li> <li>Records of pipeline failures and repairs</li> </ul>	<ul style="list-style-type: none"> <li>Calculations show that pipeline is correctly sized</li> </ul>	Rare	No issues meeting peak demand	Moderate		1	3	Low	Estimate	3	Acceptable	No

Supply Element	Hazardous Event			Hazards (associated with the hazardous event)				MAXIMUM Risk (with no preventive measures in place and all barriers failing)					RESIDUAL Risk (with existing preventive measures)							LEVEL OF UNCERTAINTY AND RISK ACCEPTABILITY						
	Event Description	Cause No.	Possible Causes	Bacteria / Viruses	Protozoa	Chemicals / Aesthetics	Disruption to Supply	Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Likelihood	Consequence of the HAZARD	Assessment Rationale - Consequence	MAX L	MAX C	Maximum (unmitigated) Risk	Existing Measures to Identify the Hazard	Existing Preventive measures	Modified Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Modified Likelihood	Modified Consequence of the HAZARD	Assessment Rationale - Modified Consequence	MOD L	MOD C	Residual Risk	Level of Uncertainty	Residual Risk Score	Risk Acceptability
Treatment - Chlorination	Inadequate Chlorination	2.01	Inadequate contact time	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Likely	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	4	4	High	<ul style="list-style-type: none"> <li>Calculation of contact time</li> <li>Continuous turbidity, pH and FAC monitoring in treated water</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Sufficient contact time in pipeline and reservoir</li> <li>Chlorine dose is always above 0.2mg/L</li> <li>UV disinfection</li> </ul>	Rare	Ample contact time in pipeline and reservoir	Moderate	UV treatment reduces consequence	1	3	Low	Reliable	3	Acceptable	No
Treatment - Chlorination	Inadequate Chlorination	2.02	<ul style="list-style-type: none"> <li>Gas chlorine supply exhausted</li> <li>Dosing system failure</li> <li>Chlorine dose rate incorrect</li> <li>Chlorine demand exceeds chlorine dose due to high turbidity</li> <li>Dosing line failure or leak</li> <li>Power failure</li> <li>Carriage water pump failure</li> <li>Freezing temperatures</li> <li>Sample point 5 hr downstream of chlorination dose point, slow response time when flow changes</li> </ul>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Likely	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	4	4	High	<ul style="list-style-type: none"> <li>Illness in community</li> <li>Continuous turbidity, pH and FAC monitoring in treated water</li> <li>FAC and E. coli monitoring in distribution system</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Operator visits the plant 1-2 times weekly to check supply of gas chlorine</li> <li>Two 70kg gas bottles with automatic changeover</li> <li>Chlorine dose rate automatically adjusts based on flow and FAC</li> <li>Chlorine gas leak sensor and alarm installed at treatment plant</li> <li>Spare carriage water pump in intake shed</li> <li>Spare tubing and fittings held by contractor</li> <li>Chlorine dosing system serviced annually by Filtec</li> <li>Operations and maintenance manual</li> <li>Standard operating procedures</li> <li>Small petrol generator available</li> <li>Trained and experienced operations staff</li> <li>UV disinfection</li> <li>Heaters in shed and checked weekly in winter</li> </ul>	Unlikely	O&M procedures and trained staff reduce likelihood	Moderate	UV treatment reduces consequence	2	3	Medium	Reliable	6	Acceptable	No
Treatment - Chlorination	Inadequate Chlorination	2.03	pH too high for chlorination to be effective	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		Unlikely	Moderate	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	2	3	Medium	<ul style="list-style-type: none"> <li>Illness in community</li> <li>Continuous turbidity, pH and FAC monitoring in treated water</li> <li>FAC and E. coli monitoring in distribution system</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>UV disinfection</li> </ul>	Unlikely	inadequate pH data to evaluate likelihood	Moderate	UV treatment reduces consequence	2	3	Medium	Certain	6	Acceptable	No
Treatment - Chlorination	Over-chlorination	2.04	<ul style="list-style-type: none"> <li>Dosing system failure</li> <li>Chlorine dosage rate is too high due to equipment malfunction or reduction in demand for chlorine in the source water</li> </ul>			<input checked="" type="checkbox"/>		Likely	Moderate	Repeated breach of MAV	4	3	High	<ul style="list-style-type: none"> <li>Continuous turbidity, pH and FAC monitoring in treated water</li> <li>FAC and E. coli monitoring in distribution system</li> <li>SCADA controls and alarms</li> <li>Odour and taste complaints</li> </ul>	<ul style="list-style-type: none"> <li>Chlorine dose rate automatically adjusts based on flow and FAC</li> <li>Operator visits the plant at least weekly to check operation of chlorination system</li> <li>Operator checks FAC in distribution system daily</li> <li>Chlorine dosing system serviced annually by Filtec</li> <li>Operations and maintenance manual</li> <li>Standard operating procedures</li> <li>Trained and experienced operations staff</li> <li>Gas chlorine less likely to overdose than hypochlorite (can't siphon)</li> </ul>	Unlikely		Moderate	PMs don't reduce consequence	2	3	Medium	Reliable	6	Acceptable	No
Treatment - Chlorination	Production of disinfection by-products	2.05	Organic material in raw water results in the production of disinfection by-products			<input checked="" type="checkbox"/>		Likely	Moderate	Repeated breach of MAV	4	3	High	<ul style="list-style-type: none"> <li>High organic loading in source water without a filtration process prior to chlorination</li> </ul>	<ul style="list-style-type: none"> <li>Gas chlorine less likely to create disinfection by-products than hypochlorite</li> </ul>	Unlikely	DBPs haven't been measured in distribution system	Moderate	PMs don't reduce consequence	2	3	Medium	Estimate	6	Unacceptable	Yes
Treatment - UV disinfection	Inadequate disinfection	2.06	UV intensity insufficient due to build-up of deposits on sleeve	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	3	4	High	<ul style="list-style-type: none"> <li>Visible build-up of deposits on sleeve</li> <li>UV intensity sensor</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Sleeve has automatic cleaning mechanism installed</li> <li>Low turbidity source water</li> <li>Chlorination</li> <li>5 yearly servicing of UV unit by Filtec</li> <li>Weekly site visits by operator</li> <li>Operations and maintenance manual</li> <li>Standard operating procedures</li> <li>Trained and experienced operations staff</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Unlikely		Major	Chlorination reduces consequence of bacterial or viral contamination but not protozoal	2	4	Medium	Reliable	8	Acceptable	No
Treatment - UV disinfection	Inadequate disinfection	2.07	Excessive turbidity in water decreases the effectiveness of the treatment	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	3	4	High	<ul style="list-style-type: none"> <li>Continuous turbidity and FAC monitoring in treated water</li> <li>FAC and E. coli monitoring in distribution system</li> <li>SCADA controls and alarms</li> <li>Illness in the community</li> </ul>	<ul style="list-style-type: none"> <li>Source water is stable with low turbidity and high UVT</li> <li>Chlorination and UV disinfection</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Rare	UVT is consistently 97-98%	Moderate	Treatment reduces consequence	1	3	Low	Reliable	3	Acceptable	No
Treatment - UV disinfection	Inadequate disinfection	2.08	Flow rate through UV unit too rapid for effective treatment	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	3	4	High	<ul style="list-style-type: none"> <li>Flow rate through plant greater than UV unit maximum</li> </ul>	<ul style="list-style-type: none"> <li>UV reactor is sized to treat maximum flow through inlet pipe (Filtec calculations)</li> <li>Flow rate based on reservoir level</li> <li>Chlorination</li> </ul>	Rare		Major	Chlorination reduces consequence of bacterial or viral contamination but not protozoal	1	4	Medium	Estimate	4	Acceptable	No
Treatment - UV disinfection	Inadequate disinfection	2.09	UV lamp failure	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	3	4	High	<ul style="list-style-type: none"> <li>UV lamp failure alarm</li> <li>UV intensity alarm</li> <li>Lamp hour meter</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>UV system is maintained at regular intervals and lamps replaced after 10,000 hours</li> <li>Spare UV lamps and sleeves kept on-site</li> <li>Weekly site visits by operator</li> <li>Operations and maintenance manual</li> <li>Standard operating procedures</li> <li>Maintenance contract KPIs</li> <li>Trained and experienced operations staff</li> <li>Chlorination</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Unlikely		Major	Chlorination reduces consequence of bacterial or viral contamination but not protozoal	2	4	Medium	Confident	8	Acceptable	No
Treatment - UV disinfection	Inadequate disinfection	2.10	UV intensity sensor failure	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	3	4	High	<ul style="list-style-type: none"> <li>UV intensity alarm</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>UV systems are maintained at regular intervals with sensor checked or replaced annually</li> <li>Spare UV sensor kept on-site</li> <li>Weekly site visits by operator</li> <li>Operations and maintenance manual</li> <li>Standard operating procedures</li> <li>Maintenance contract KPIs</li> <li>Trained and experienced operations staff</li> <li>Chlorination</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Unlikely		Major	Chlorination reduces consequence of bacterial or viral contamination but not protozoal	2	4	Medium	Confident	8	Acceptable	No

Tekapo Water Supply - Risk Assessment Table



Supply Element	Hazardous Event			Hazards (associated with the hazardous event)				MAXIMUM Risk (with no preventive measures in place and all barriers failing)					RESIDUAL Risk (with existing preventive measures)							LEVEL OF UNCERTAINTY AND RISK ACCEPTABILITY						
	Event Description	Cause No.	Possible Causes	Bacteria / Viruses	Protozoa	Chemicals / Aesthetics	Disruption to Supply	Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Likelihood	Consequence of the HAZARD	Assessment Rationale - Consequence	MAX L	MAX C	Maximum (unmitigated) Risk	Existing Measures to Identify the Hazard	Existing Preventive measures	Modified Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Modified Likelihood	Modified Consequence of the HAZARD	Assessment Rationale - Modified Consequence	MOD L	MOD C	Residual Risk	Level of Uncertainty	Residual Risk Score	Risk Acceptability
Treatment - UV disinfection	Inadequate disinfection	2.11	Power failure resulting in UV unit being unable to operate	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Likely	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	4	4	High	<ul style="list-style-type: none"> <li>Notice of power failure</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Mobile generator can be setup (no direct connection)</li> <li>Chlorination</li> <li>plant shutdown on UV failure</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Unlikely		Major	Chlorination reduces consequence of bacterial or viral contamination but not protozoal	2	4	Medium	Reliable	8	Acceptable	No
Treatment	Fire within treatment plant building	2.12	<ul style="list-style-type: none"> <li>Faulty switchboard or other malfunction</li> <li>Vandalism or sabotage</li> </ul>				<input checked="" type="checkbox"/>	Possible	Major		3	4	High	<ul style="list-style-type: none"> <li>Obvious signs of damage to structure</li> <li>Reported by residents</li> </ul>	<ul style="list-style-type: none"> <li>Concrete block building</li> <li>Surge protection</li> <li>Yearly electrical inspection</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Rare		Major		1	4	Medium	Reliable	4	Acceptable	No
Post-Treatment - Storage	Microbiological Contamination	3.01	<ul style="list-style-type: none"> <li>Access by birds or vermin</li> <li>Leakage through reservoir roof or other parts of structure</li> </ul>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	3	4	High	<ul style="list-style-type: none"> <li>Visual evidence of leakage</li> <li>Condition assessment</li> <li>FAC and E. coli monitoring in distribution system</li> <li>Monthly inspection of reservoir by Contractor</li> </ul>	<ul style="list-style-type: none"> <li>Chlorine residual</li> <li>Reservoir is covered and all entry hatches are secured and locked against unauthorised access</li> <li>Grates over vents</li> <li>Reservoir is in good condition, walls and floors were spray lined with rubber in 2018</li> </ul>	Unlikely	Grates prevent access by larger vermin but not insects	Moderate	Chlorine residual reduces consequence	2	3	Medium	Reliable	6	Acceptable	No
Post-Treatment - Storage	Microbiological or chemical contamination	3.02	Vandalism to reservoir	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		Possible	Moderate	Potential repeated exceedance of MAV	3	3	Medium	<ul style="list-style-type: none"> <li>FAC and E. coli monitoring in distribution system</li> <li>Reports from the neighbour or the public</li> </ul>	<ul style="list-style-type: none"> <li>Chlorine residual</li> <li>Reservoir is covered and all entry hatches are secured and locked against unauthorised access</li> <li>Reservoir is overlooked by nearby house and on private land</li> </ul>	Unlikely	Reservoir security reduce likelihood	Moderate	Chlorine residual reduces consequence	2	3	Medium	Reliable	6	Acceptable	No
Post-Treatment - Storage	Aesthetic Contamination	3.03	Sediment accumulation and release from reservoir			<input checked="" type="checkbox"/>		Possible	Moderate	Potential widespread aesthetic issues	3	3	Medium	<ul style="list-style-type: none"> <li>Visible suspended matter in water exiting reservoir</li> <li>FAC and E. coli monitoring in distribution system</li> <li>Customer complaints</li> </ul>	<ul style="list-style-type: none"> <li>Source has very low sediment load and low turbidity</li> <li>Minimum operating level in reservoir is maintained</li> <li>Drain at bottom of reservoir, reservoir can be bypassed and cleaned out if required</li> <li>Reservoir was cleaned when lined in 2018</li> </ul>	Rare	Low turbidity in source water reduces likelihood	Moderate	PMs don't reduce consequence	1	3	Low	Reliable	3	Acceptable	No
Post-Treatment - Storage	Loss of Supply	3.04	Failure of reservoir e.g. due to structural failure or earthquake damage				<input checked="" type="checkbox"/>	Unlikely	Catastrophic	Major impact on most of the population, complete failure of systems, requirement for high level of monitoring and incident management	2	5	High	<ul style="list-style-type: none"> <li>Customer complaints</li> <li>Obvious signs of leakage or failure at reservoir site</li> <li>Monthly inspection of reservoir by Contractor</li> <li>Reservoir level indicator</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Reservoir is constructed of concrete and is in good condition, recently lined to prevent leakage</li> <li>Reservoir can be bypassed and water supplied directly to reticulation</li> <li>Water restrictions</li> <li>Use of tankered water</li> </ul>	Unlikely	Reservoir condition reduces likelihood	Moderate	Reservoir bypass reduces consequence	2	3	Medium	Reliable	6	Acceptable	No
Post-Treatment - Storage	Loss of Supply	3.05	Insufficient storage for peak demand				<input checked="" type="checkbox"/>	Likely	Major	Significant compromise of systems and abnormal operation	4	4	High	<ul style="list-style-type: none"> <li>Customer complaints</li> <li>Reservoir level indicator</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>More than 10 hours of stored treated water at peak demand</li> <li>Water restrictions</li> <li>Use of tankered water</li> </ul>	Possible	No issues meeting peak demand	Moderate		3	3	Medium	Reliable	9	Acceptable	No
Reticulation	Loss of Supply	4.01	Failure of critical supply main from reservoir to town due to break, structural failure or contractor damage				<input checked="" type="checkbox"/>	Possible	Catastrophic	Major impact on most of the population, complete failure of systems, requirement for high level of monitoring and incident management	3	5	High	<ul style="list-style-type: none"> <li>Customer complaints</li> <li>Pipeline condition assessment</li> <li>Reservoir level indicator</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Pipe failures are repaired as a priority by maintenance contractor</li> <li>Maintenance contract KPIs</li> <li>Pipe renewals programme</li> <li>Pipe location on Canterbury Maps GIS</li> <li>Water restrictions</li> <li>Use of tankered water</li> </ul>	Rare	Pipe sample recovered in 2020, assessed as Grade 3 - Moderate condition. Unlikely to be at risk of failure until 2050.	Catastrophic	PMs don't reduce consequence	1	5	Medium	Reliable	5	Acceptable	No
Reticulation	Loss of Supply	4.02	<ul style="list-style-type: none"> <li>Excessive demand in the network</li> <li>Inadequate distribution system capacity</li> <li>Failure of booster pump station</li> </ul>				<input checked="" type="checkbox"/>	Possible	Moderate		3	3	Medium	<ul style="list-style-type: none"> <li>Customer complaints</li> <li>Reservoir level indicator</li> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Pipe renewals programme</li> <li>Booster pump station only supplies elevated houses during peak periods, can supply by gravity most of the time</li> <li>Water restrictions</li> <li>Use of tankered water</li> </ul>	Rare	No issues meeting peak demand	Moderate		1	3	Low	Reliable	3	Acceptable	No
Reticulation	Microbiological Contamination	4.03	<ul style="list-style-type: none"> <li>Inadequate controls on maintenance and construction work</li> <li>Contractors other than the nominated maintenance contractors carry out work on the water supply network</li> </ul>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible	Moderate		3	3	Medium	<ul style="list-style-type: none"> <li>Complaints from consumers about taste or odour</li> <li>E. coli present in reticulation system</li> <li>Less than expected FAC in reticulation</li> <li>Contractor or staff notification</li> </ul>	<ul style="list-style-type: none"> <li>Chlorine residual</li> <li>Only Council approved contractors can work on the water supply network</li> <li>Maintenance and replacement work is undertaken by trained qualified and experienced contractors</li> </ul>	Unlikely		Moderate		2	3	Medium	Reliable	6	Acceptable	No
Reticulation	Microbiological Contamination	4.04	Contaminants permeate from pipeline installed in contaminated land			<input checked="" type="checkbox"/>		Unlikely	Moderate	Repeated breach of maximum acceptable value	2	3	Medium	<ul style="list-style-type: none"> <li>Customer complaints</li> <li>Water quality monitoring</li> <li>Resource consents for contaminant plumes</li> </ul>	<ul style="list-style-type: none"> <li>HAIL (hazardous activities and industries list) sites checked when building new subdivisions</li> </ul>	Unlikely		Moderate		2	3	Medium	Reliable	6	Acceptable	No
Reticulation	Microbiological Contamination	4.05	Standard hygiene practices not adhered to or inadequate flushing and disinfection practices during repairs or commissioning of new mains and new connections	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	3	4	High	<ul style="list-style-type: none"> <li>FAC monitoring</li> <li>contractor reports breach of disinfection procedure</li> </ul>	<ul style="list-style-type: none"> <li>Chlorine residual</li> <li>Only Council approved contractors can work on the water supply network</li> <li>Council audit of contractors</li> <li>Maintenance contractor follows 'chain of cleanliness'</li> <li>Water main disinfection and water quality testing after mains repairs</li> <li>Maintenance contractor follows contractor plans and uses disinfection when carrying out repairs</li> </ul>	Possible		Moderate	Chlorine residual reduces consequence	3	3	Medium	Reliable	9	Acceptable	No



Supply Element	Hazardous Event			Hazards (associated with the hazardous event)				MAXIMUM Risk (with no preventive measures in place and all barriers failing)						RESIDUAL Risk (with existing preventive measures)						LEVEL OF UNCERTAINTY AND RISK ACCEPTABILITY						
	Event Description	Cause No.	Possible Causes	Bacteria / Viruses	Protozoa	Chemicals / Aesthetics	Disruption to Supply	Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Likelihood	Consequence of the HAZARD	Assessment Rationale - Consequence	MAX L	MAX C	Maximum (unmitigated) Risk	Existing Measures to Identify the Hazard	Existing Preventive measures	Modified Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Modified Likelihood	Modified Consequence of the HAZARD	Assessment Rationale - Modified Consequence	MOD L	MOD C	Residual Risk	Level of Uncertainty	Residual Risk Score	Risk Acceptability
Reticulation	Microbiological Contamination	4.06	Breaks / leaks due to pipe condition or significant flow and pressure fluctuations, or accidental damage to water mains	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Possible	Major	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	3	4	High	<ul style="list-style-type: none"> <li>Visual inspection</li> <li>Water quality monitoring</li> <li>Customer complaints</li> <li>Reports from contractors</li> <li>Reports of illness</li> </ul>	<ul style="list-style-type: none"> <li>Chlorine residual</li> <li>Gravity flow provides a minimum pressure and flow</li> <li>Only Council approved contractors can work on the water supply network</li> <li>Pipe locations on Canterbury Maps</li> <li>Council audit of contractors</li> <li>Maintenance contractor follows 'chain of cleanliness'</li> <li>Pipe failures are repaired as priority (maintenance contract KPIs)</li> <li>Asset knowledge is held on pipe ages, material and condition</li> <li>Mostly new PE and PVC network</li> <li>Failures, maintenance and renewals are recorded in Council asset management system</li> <li>Pipeline renewals programme</li> <li>Treated water storage</li> <li>Water restrictions</li> <li>Use of tankered water</li> </ul>	Unlikely	Contractor processes and audits, and mostly new PE and PVC network reduce likelihood	Moderate	Chlorine residual reduces consequence	2	3	Medium	Reliable	6	Acceptable	No
Reticulation	Microbiological Contamination	4.07	Cross contamination from wastewater and water supply sampling	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Likely	Assumes no sampling controls	Potential acute harm to people, declared outbreak or widespread illness and possible deaths expected	4	4	High	<ul style="list-style-type: none"> <li>Contaminants identified in the reticulation system.</li> <li>Taste or odour complaints from consumers.</li> </ul>	<ul style="list-style-type: none"> <li>Chlorine residual</li> <li>Water supply samples are taken separately to wastewater samples</li> <li>Trained and experienced water sampling staff</li> <li>Backup sampling staff available</li> <li>Standard operating procedures</li> </ul>	Unlikely		Minor	Chlorine residual reduces consequence	2	2	Low	Estimate	4	Acceptable	No
Reticulation	Chemical/Microbiological Contamination	4.08	Backflow from consumer connections	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Likely	Major	Repeated breach of maximum acceptable value	4	4	High	<ul style="list-style-type: none"> <li>Contaminants identified in the reticulation system.</li> <li>Taste or odour complaints from consumers.</li> </ul>	<ul style="list-style-type: none"> <li>Gravity flow provides a minimum pressure and flow</li> <li>Chlorine residual</li> </ul>	Likely	RPZs on wastewater wet wells, minimum pressure and flow reduces likelihood of backflow	Major		4	4	High	Estimate	16	Unacceptable	Yes
Reticulation	Loss of water	4.09	Unidentified leakage or illegal connections	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Likely	Moderate		4	3	High	<ul style="list-style-type: none"> <li>Consumption exceeds calculated expectation</li> </ul>	<ul style="list-style-type: none"> <li>Known breaks and leaks repaired as a priority (maintenance contract KPIs)</li> <li>Disconnect or legitimise illegal connections</li> <li>Estimated 20% leakage, minimum overnight flow unknown</li> </ul>	Possible	Leakage ~20%	Minor		3	2	Medium	Reliable	6	Acceptable	No
Reticulation	Supply of Turbid Water	4.10	Silt build up within reticulation pipes	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Possible	Minor		3	2	Medium	<ul style="list-style-type: none"> <li>Reduced flows in reticulation.</li> <li>Complaints from consumer about quality of water</li> </ul>	<ul style="list-style-type: none"> <li>Low turbidity source water</li> <li>Flushing undertaken if required in response to complaints</li> <li>Very few dead ends in network</li> </ul>	Rare	No complaints	Minor		1	2	Low	Estimate	2	Acceptable	No
Reticulation	Inadequate Supply of Water	4.11	Poor quality workmanship or inappropriate materials used for reticulation pipes and fittings	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	Possible	Moderate	Significant disruption to normal operation	3	3	Medium	<ul style="list-style-type: none"> <li>Contaminants identified in the reticulation system.</li> <li>Taste and odour complaints from consumers</li> <li>Reduced FAC in water</li> </ul>	<ul style="list-style-type: none"> <li>Council requires all work and materials used in reticulation to meet standard specifications</li> <li>Best practice reticulation approach taken to reticulation work</li> </ul>	Unlikely		Moderate		2	3	Medium	Reliable	6	Acceptable	No
Reticulation	Chemical Contamination	4.12	Low alkalinity or pH causes leaching of metals from pipes and fittings into the treated water supply	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Possible	Moderate	Significant disruption to normal operation	3	3	Medium	<ul style="list-style-type: none"> <li>Rate of pipe failures is higher than expected</li> <li>Complaints about hot water cylinder failures</li> <li>pH, alkalinity and hardness</li> <li>Langelier saturation index of water</li> <li>pH of water is analysed bi-annually</li> </ul>		Possible		Moderate		3	3	Medium	Reliable	9	Acceptable	No
Systems and Processes	Sampling failure	5.01	Inadequate sampling programme or sample collection error.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Likely	Moderate		4	3	High	<ul style="list-style-type: none"> <li>DWSNZ compliance failure due to days of week, days between samples, insufficient samples, information gaps, positive results or sampling error</li> </ul>	<ul style="list-style-type: none"> <li>Sampling programme prepared and checked against DWSNZ</li> </ul>	Possible		Moderate		3	3	Medium	Reliable	9	Acceptable	No
Systems and Processes	Incorrect or inadequate water quality data used for water supply management	5.02	Not enough sampling points	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Likely	Insignificant		4	1	Medium	<ul style="list-style-type: none"> <li>Drinking water compliance audits identify missing or incorrect sample results</li> </ul>	<ul style="list-style-type: none"> <li>Sufficient sampling points</li> </ul>	Possible		Insignificant		3	1	Low	Estimate	3	Acceptable	No
Systems and Processes	Unidentified Operational Failure	5.03	Insufficient monitoring and alarming of key operational data	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Possible	Moderate		3	3	Medium	<ul style="list-style-type: none"> <li>SCADA controls and alarms</li> </ul>	<ul style="list-style-type: none"> <li>Manual sampling of chlorine process</li> <li>Continuous monitoring and SCADA</li> </ul>	Unlikely		Major		2	4	Medium	Reliable	8	Acceptable	No
Systems and Processes	Failure of supply	5.04	Insufficient, inadequate, out of date or incorrect manual of operational procedures.	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	Almost Certain	Moderate		5	3	High	<ul style="list-style-type: none"> <li>Operational Manuals not up to date / require review</li> </ul>	<ul style="list-style-type: none"> <li>O&amp;M manual updated in 2019</li> <li>Standard operating procedures</li> </ul>	Unlikely		Moderate		2	3	Medium	Reliable	6	Acceptable	No
Systems and Processes	Failure due to Inadequate Maintenance	5.05	Supply equipment fails due to inadequate asset information and inadequate maintenance planning	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Almost Certain	Moderate		5	3	High	<ul style="list-style-type: none"> <li>Unexpected plant equipment failure.</li> <li>Not having an asset register and maintenance programme</li> </ul>	<ul style="list-style-type: none"> <li>Very little in the way of treatment equipment at this supply</li> <li>Council and contractor have a good understanding of water supply assets allowing maintenance to be planned and undertaken</li> <li>Failure are attended to as a priority (maintenance contract KPIs)</li> <li>Asset knowledge is held on pipe ages, material and condition</li> <li>Water supply renewals programme in Long Term Plan</li> </ul>	Unlikely		Moderate		2	3	Medium	Reliable	6	Acceptable	No
Systems and Processes	Operator Error or Mismanagement	5.06	<ul style="list-style-type: none"> <li>Insufficient qualified and experienced operators to operate and manage the water treatment plant to meet DWSNZ compliance requirements</li> <li>Inadequate training, professional development and up-skilling of operators</li> </ul>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Almost Certain	Major		5	4	Extreme	<ul style="list-style-type: none"> <li>Poor operation of plant.</li> <li>Plant compliance failure.</li> <li>Loss of supply.</li> <li>Audits</li> <li>DWSNZ compliance</li> <li>Operational issues</li> <li>Staff feedback</li> <li>Failure to comply with QA procedures</li> </ul>	<ul style="list-style-type: none"> <li>Operator has Level 4 Water Treatment qualification and 1 other is in training for Level 4 Water Treatment</li> <li>Provide in-house training where abilities are in deficit</li> <li>Operations and maintenance manual</li> <li>Standard operating procedures</li> <li>Maintenance contract has requirement for qualified staff</li> </ul>	Possible		Moderate		3	3	Medium	Reliable	9	Acceptable	No
Systems and Processes	Water treatment technician error or mismanagement	5.07	Loss of staff, inability to attract and retain staff	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input checked="" type="checkbox"/>	Possible	Major		3	4	High	<ul style="list-style-type: none"> <li>Resignations / staff turnover</li> <li>Poor operation of plant</li> <li>Plant compliance failure</li> <li>Loss of supply</li> </ul>	<ul style="list-style-type: none"> <li>Automated treatment processes</li> <li>Standard operating procedures</li> <li>Succession planning</li> <li>On-going training and up-skilling is provided for Water Treatment Technicians</li> </ul>	Unlikely		Major		2	4	Medium	Reliable	8	Acceptable	No



Tekapo Water Supply - Risk Assessment Table



Supply Element	Hazardous Event			Hazards (associated with the hazardous event)				MAXIMUM Risk (with no preventive measures in place and all barriers failing)					RESIDUAL Risk (with existing preventive measures)							LEVEL OF UNCERTAINTY AND RISK ACCEPTABILITY							
	Event Description	Cause No.	Possible Causes	Bacteria / Viruses	Protozoa	Chemicals / Aesthetics	Disruption to Supply	Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Likelihood	Consequence of the HAZARD	Assessment Rationale - Consequence	MAX L	MAX C	Maximum (unmitigated) Risk	Existing Measures to Identify the Hazard	Existing Preventive measures	Modified Likelihood of HAZARDOUS EVENT occurring	Assessment Rationale - Modified Likelihood	Modified Consequence of the HAZARD	Assessment Rationale - Modified Consequence	MOD L	MOD C	Residual Risk	Level of Uncertainty	Residual Risk Score	Risk Acceptability	Additional Preventive Measure Required?
Systems and Processes	Failure to Provide Safe Water	5.08	Inadequate data collection, reporting and control systems	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Likely		Moderate		4	3	High	<ul style="list-style-type: none"> <li>Information about how the supply is operating is not available</li> <li>Continuous monitoring of pH, turbidity and FAC in treated water plus manual sampling</li> </ul>	<ul style="list-style-type: none"> <li>FAC and turbidity results</li> <li>Recording of manual sampling results</li> <li>Sample schedule is prepared in accordance with DWSNZ</li> </ul>	Unlikely		Moderate		2	3	Medium	Reliable	6	Acceptable	No
Systems and Processes	Failing to meet the requirements of the DWSNZ	5.09	Treatment processes are not sufficient to comply with the requirements of the DWSNZ	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Almost Certain		Major		5	4	Extreme	<ul style="list-style-type: none"> <li>Treatment processes comply with DWSNZ requirements</li> </ul>	<ul style="list-style-type: none"> <li>Chlorination and UV</li> <li>Continuous monitoring</li> <li>Low risk catchment</li> <li>Low turbidity source water</li> </ul>	Rare		Moderate		1	3	Low	Reliable	3	Acceptable	No
Systems and Processes	Civil emergency	5.10	Catastrophic natural disaster or failure including earthquake, flooding etc.	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Unlikely		Catastrophic		2	5	High	<ul style="list-style-type: none"> <li>Major natural disaster occurs</li> <li>Intense sustained weather</li> <li>Land slide, flooding, volcanic eruption</li> <li>Total plant failure is evident</li> <li>Warnings from Govt agencies incl Met Office, NIWA, Civil Defence, Regional Council or Police</li> </ul>	<ul style="list-style-type: none"> <li>Prior warning from Govt agencies incl Met Office, Niwa, Civil Defence, Regional Council or Police</li> <li>Robust secure plant structures and buildings</li> <li>Implement all measures necessary to ensure plant continues to operate in a natural disaster</li> <li>Chlorination and UV</li> <li>Chlorine residual</li> <li>Water restrictions</li> <li>Treated water storage</li> <li>Use of tankered water</li> </ul>	Rare		Major		1	4	Medium	Reliable	4	Acceptable	No
Systems and Processes	Operator, contractor and other management issues	5.11	Inadequate QA / management systems	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible		Minor		3	2	Medium	<ul style="list-style-type: none"> <li>Third party audits</li> </ul>	<ul style="list-style-type: none"> <li>Contract audits and QA</li> <li>Laboratory is IANZ accredited and Taumata Arowai approved</li> </ul>	Unlikely		Minor		2	2	Low	Reliable	4	Acceptable	No
Systems and Processes	Operator, contractor and other management issues	5.12	Inadequate supply planning and management	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>			Possible		Major		3	4	High	<ul style="list-style-type: none"> <li>Third party audits</li> <li>DWSNZ compliance</li> <li>Operational issues</li> <li>Budgets exceeded due to unplanned reactive work</li> </ul>	<ul style="list-style-type: none"> <li>Asset management plan</li> <li>Infrastructure strategy</li> <li>Long Term Plan</li> <li>Suitably qualified and experienced staff at Council</li> </ul>	Unlikely		Moderate		2	3	Medium	Reliable	6	Acceptable	No
Systems and Processes	Operator, contractor and other management issues	5.12	Not updating/reviewing risks in the water safety plan following incidents or major changes to the water supply	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>		<input checked="" type="checkbox"/>	Likely		Minor		4	2	Medium	<ul style="list-style-type: none"> <li>Water safety plan audits</li> </ul>	<ul style="list-style-type: none"> <li>Continual tracking of progress against improvement actions in water safety plan</li> </ul>	Possible		Moderate		3	3	Medium	Reliable	9	Acceptable	No
Systems and Processes	disruption to operation of water treatment processes or SCADA	5.13	Cyber security attack				<input checked="" type="checkbox"/>	Rare		Moderate		1	3	Low	<ul style="list-style-type: none"> <li>IT security reviews</li> <li>Disruption to supply management systems</li> </ul>	<ul style="list-style-type: none"> <li>Running two systems: SCADA and Industrial Control (one system would flag issues with the other)</li> <li>Can manually operate plant if required</li> <li>SCADA is read-only so if unauthorised access occurs the impact would be minimal</li> </ul>	Rare		Minor		1	2	Low	Reliable	2	Acceptable	No

Appendix B  
National Policy Statement  
for Freshwater Management  
2020 (NPSFM) and  
Canterbury Land and Water  
Regional Plan  
Requirements

## National Requirements

The National Policy Statement for Freshwater Management 2020 (NPSFM) contains an objective and policies relating to safeguarding New Zealand's freshwater values. These impose directions primarily on Regional Councils who then need to ensure that regional plans give effect to those directions.

The following objective of the NPSFM is relevant to protecting drinking water supplies.

1. *The objective of this National Policy Statement is to ensure that natural and physical resources are managed in a way that prioritises:*
  - a. *first, the health and well-being of water bodies and freshwater ecosystems*
  - b. *second, the health needs of people (such as drinking water)*
  - c. *third, the ability of people and communities to provide for their social, economic, and cultural well-being, now and in the future.*

The following policies give effect to the above objective and are considered relevant to protecting the Takapō/Tekapo drinking water supply:

Policy 1	<i>Freshwater is managed in a way that gives effect to Te Mana o te Wai.</i>
Policy 3	<i>Freshwater is managed in an integrated way that considers the effects of the use and development of land on a whole-of-catchment basis, including the effects on receiving environments.</i>
Policy 5	<i>Freshwater is managed through a National Objectives Framework to ensure that the health and well-being of degraded water bodies and freshwater ecosystems is improved, and the health and well-being of all other water bodies and freshwater ecosystems is maintained and (if communities choose) improved.</i>
Policy 7	<i>The loss of river extent and values is avoided to the extent practicable.</i>
Policy 11	<i>Freshwater is allocated and used efficiently, all existing over-allocation is phased out, and future over-allocation is avoided.</i>
Policy 12	<i>The national target (as set out in Appendix 3) for water quality improvement is achieved.</i>
Policy 13	<i>The condition of water bodies and freshwater ecosystems is systematically monitored over time, and action is taken where freshwater is degraded, and to reverse deteriorating trends.</i>
Policy 14	<i>Information (including monitoring data) about the state of water bodies and freshwater ecosystems, and the challenges to their health and well-being, is regularly reported on and published.</i>

The following specific requirements of the NPSFM are relevant to the management of freshwater and must also be implemented by Regional Councils.

### 3.24 Rivers<sup>12</sup>

1. *Every regional council must include the following policy (or words to the same effect) in its regional plan(s):*
  - “The loss of river extent and values is avoided, unless the council is satisfied:*
    - a. *that there is a functional need for the activity in that location; and*
    - b. *the effects of the activity are managed by applying the effects management hierarchy.”*
2. *Subclause (3) applies to an application for a consent for an activity:*
  - a. *that falls within the exception to the policy described in subclause (1); and*
  - b. *would result (directly or indirectly) in the loss of extent or values of a river.*

---

<sup>12</sup> A river is defined in the Resource Management Act 1991 as a continually or intermittently flowing body of fresh water; and includes a stream and modified watercourse; but does not include any artificial watercourse (including an irrigation canal, water supply race, canal for the supply of water for electricity power generation, and farm drainage canal).

3. *Every regional council must make or change its regional plan(s) to ensure that an application referred to in subclause (2) is not granted unless:*
  - a. *the council is satisfied that the applicant has demonstrated how each step in the effects management hierarchy will be applied to any loss of extent or values of the river (including cumulative effects and loss of potential value), particularly (without limitation) in relation to the values of: ecosystem health, indigenous biodiversity, hydrological functioning, Māori freshwater values, and amenity; and*
  - b. *any consent granted is subject to conditions that apply the effects management hierarchy.*
4. *Every regional council must:*
  - a. *develop and undertake a monitoring plan that:*
    - i. *monitors the condition of its rivers; and*
    - ii. *contains sufficient information to enable the council to assess whether its policies, rules, and methods are ensuring no loss of extent or values of the rivers; and*
  - b. *have methods to respond if loss of extent or values is detected.*

## Canterbury Land and Water Regional Plan

The Canterbury Land and Water Regional Plan (CLWRP) contains a number of objectives and policies that are relevant to protecting the values of the Takapō/Tekapo drinking water supply.

Objective 3.2	Water management applies the ethic of ki uta ki tai – from the mountains to the sea – and land and water are managed as integrated natural resources recognising the connectivity between surface water and groundwater, and between fresh water, land and the coast.
Objective 3.6	Water is recognised as essential to all life and is respected for its intrinsic values.
Objective 3.7	Fresh water is managed prudently as a shared resource with many in-stream and out-of-stream values.
Objective 3.8	The quality and quantity of water in fresh water bodies and their catchments is managed to safeguard the life-supporting capacity of ecosystems and ecosystem processes, including ensuring sufficient flow and quality of water to support the habitat and feeding, breeding, migratory and other behavioural requirements of indigenous species, nesting birds and, where appropriate, trout and salmon.
Objective 3.12	When setting and managing within limits, regard is had to community outcomes for water quality and quantity.
Objective 3.13	Groundwater resources remain a sustainable source of high quality water which is available for abstraction while supporting base flows or levels in surface water bodies, springs and wetlands and avoiding salt-water intrusion.
Objective 3.16	Freshwater bodies and their catchments are maintained in a healthy state, including through hydrological and geomorphic processes such as flushing and opening hāpua and river mouths, flushing algal and weed growth, and transporting sediment.
Objective 3.23	Soils are healthy and productive, and human-induced erosion and contamination are minimised.
Objectives 3.24	All activities operate at good environmental practice or better to optimise efficient resource use and protect the region’s fresh water resources from quality and quantity degradation.
Policy 4.1	Lakes, rivers, wetlands and aquifers will meet the fresh water outcomes set in Sections 6 to 15 within the specified timeframes. If outcomes have not been established for a catchment, then each type of lake, river or aquifer should meet the outcomes set out in Table 1 by 2030.

Policy 4.2 The management of lakes, rivers, wetlands and aquifers will take account of the fresh water outcomes, water quantity limits and the individual and cumulative effects of land uses, discharges and abstractions will meet the water quality limits set in Sections 6 to 15 or Schedule 8 and the individual and cumulative effects of abstractions will meet the water quantity limits in Sections 6 to 15.

Policy 4.4 Groundwater is managed so that:

- (a) groundwater abstractions do not cause a continuing long-term decline in mean annual groundwater levels or artesian pressures;
- (b) the individual and cumulative rate, duration and volume of water pumped from bores is controlled so as to prevent seawater contamination;
- (c) the rate and duration of individual abstractions is controlled to ensure that individually or cumulatively, localised pressure reversal does not result in the downward movement of contaminants;
- (d) in any location where an overall upwards pressure gradient exists, restrict the taking of groundwater so that at all times the overall upward pressure difference is maintained between any one aquifer and the next overlying aquifer;
- (e) overall water quality in aquifers does not decline; and
- (f) the exercise of customary uses and values is supported.

Policy 4.5 Water is managed through the setting of limits to safeguard the life-supporting capacity of ecosystems, support customary uses, and provide for community drinking-water supplies and stock water, as a first priority and to meet the needs of people and communities for water for irrigation, hydro-electricity generation and other economic activities and to maintain river flows and lake levels needed for recreational activities, as a second priority.

Policy 4.7 Resource consents for new or existing activities will not be granted if the granting would cause a water quality or quantity limit set in Sections 6 to 15 to be breached or further over allocation (water quality and/or water quantity) to occur or in the absence of any water quality standards in Sections 6 to 15, the limits set in Schedule 8 to be breached. Replacement consents, or new consents for existing activities may be granted to:

- (a) allow the continuation of existing activities at the same or lesser rate or scale, provided the consent contains conditions that contribute to the phasing out of the over allocation (water quality and/or water quantity) within a specified timeframe; or
- (b) exceed the allocation limit (water quality and/or water quantity) to a minor extent and in the short-term if that exceedance is part of a proposal to phase out the overallocation within a specified timeframe included in Sections 6 to 15 of this Plan.

Policies 4.12-22, 24-69 & 75-98 Seeks to protect the environment by managing how the following activities are undertaken:

- Discharge of contaminants to land or water
- Stormwater and community wastewater systems
- Earthworks, land excavation and deposition of material into land over aquifers
- Soil stability

- Hazardous substances and hazardous activities
- Livestock exclusion from waterways
- Discharges of collected animal effluent
- Nutrient management
- Damming and diversion of water bodies
- Abstraction and efficient use of water
- Flow sensitive catchments
- Site dewatering
- Hydrocarbon exploration or production, including 'fracking'
- Fine sediment removal and habitat restoration
- Gravel extraction

Policy 4.23 Any water source used for drinking-water supply is protected from any discharge of contaminants that may have any actual or potential adverse effect on the quality of the drinking-water supply including its taste, clarity and smell and community drinking water supplies are protected so that they align with the CWMS drinking-water targets and meet the drinking-water standards for New Zealand.

Policy 4.23A The quality of water abstracted from community drinking-water supply sources is protected through:

- (a) the application of a provisional protection zone around the source of any existing community drinking-water supply, unless a specific protection zone is included as a condition in the permit to take or use water; and
- (b) requiring applications for new or replacement permits to take or use water for community drinking-water supply to include an assessment of the specific protection zone required, taking into account the factors set out in Schedule 1; and
- (c) providing, by way of resource consent, for the replacement of provisional protection zones with specific protection zones which reflect the level of protection required for that supply.

Policy 4.23B In considering resource consent applications to take or use water for a community drinking water supply, the consent authority shall have regard to:

- (a) the factors set out in Schedule 1; and
- (b) the extent to which the application reflects those factors set out in Schedule 1 when establishing the extent of the proposed protection zone; and
- (c) the level of additional restriction the proposed protection zone will impose on land users within the proposed protection zone.

Policy 15B.4.2 Protect wāhi tapu and wāhi taonga values in the Waitaki by avoiding or mitigating the adverse effects of land use intensification on wāhi tapu or wāhi taonga.

Policy 15B.4.7 Water quality is maintained by:

- (a) restricting any discharge of sewage sludge, bio-solids or treated sewage effluent from a community wastewater treatment system to the relevant nitrogen load limit in Table 15B(h), unless the exceedance is less than the

nitrogen load contribution from the aggregation of on-site domestic wastewater treatment systems that would be replaced by the community wastewater system; and

(b) adoption of the best practicable option to treat and manage the discharge.

Policies 15B.4.11-13 &  
16-17

Seeks to manage nutrient discharges from farming activities.



wsp

[wsp.com/nz](http://wsp.com/nz)